

# ENTSO-E Draft Network Code on High Voltage Direct Current Connections and DC-connected Power Park Modules

3 March 2014

## **Notice**

This document reflects the status of the work of Transmission System Operator experts as of 3 March 2014 in line with the ACER Framework Guidelines on Electricity Grid Connections published on 21 July 2011, after the EC mandate letter was received by ENTSO-E on 29 April 2013. It reflects the comments received by ENTSO-E during the Call for Stakeholder Input consultation held between 7 May 2013 and 7 June 2013, and a formal public consultation in accordance with the provisions of the Article 10 of Regulation (EC) N°714/2009 during November and December 2013. Furthermore, it is based on the input received through extensive dialogue with stakeholders, as well as bilateral/ trilateral meetings with ACER and with the European Commission.

The document does not in any case represent a firm, binding or definitive ENTSO-E position on the content, the structure or the prerogatives of the Network Code on High Voltage Direct Current Connections and DC-connected Power Park Modules, which will be submitted to ACER by 1 May 2014.

THE EUROPEAN COMMISSION,

Having regard to the Treaty on the Functioning of the European Union,

Having regard to Directive 2009/72/EC of the European Parliament and of the Council of 13 July 2009 concerning common rules for the internal market in electricity and repealing Directive 2003/54/EC,

Having regard to Regulation (EC) No 713/2009 of the European Parliament and of the Council of 13 July 2009 establishing an Agency for the Cooperation of Energy Regulators (ACER),

Having regard to Regulation (EC) No 714/2009 of the European Parliament and of the Council of 13 July 2009 on conditions for access to the network for cross-border exchanges in electricity and repealing Regulation (EC) No 1228/2003 and especially Article 6,

Having regard to the Framework Guideline on Electricity Grid Connections issued by the Agency for the Coordination of Energy Regulators on 21 July 2011,

Whereas:

- (1) Directive 2009/72/EC of the European Parliament and of the Council of 13 July 2009 concerning common rules for the internal market in electricity and repealing Directive 2003/54/EC and Regulation (EC) No 714/2009 of the European Parliament and of the Council of 13 July 2009 underline the need for an increased cooperation and coordination among transmission system operators within a European Network of Transmission System Operators for Electricity (ENTSO-E) to create Network Codes for providing and managing effective and transparent access to the transmission networks across borders, and to ensure coordinated and sufficiently forward-looking planning and sound technical evolution of the transmission system in the European Union, including the creation of interconnection capacities, with due regard to the environment.
- (2) Transmission System Operators (TSO(s)) are according to Article 2 and 12 of Directive 2009/72/EC responsible for providing and operating high and extra-high Voltage networks for long-distance transmission of electricity as well as for supply of lower-level regional distribution systems and directly connected customers. Besides this transmission and supply task it is also the TSO(s)' responsibility to ensure the system security with a high level of reliability and quality.
- (3) ENTSO-E has drafted this Network Code on HVDC Connections and DC-connected Power Park Modules aiming at setting out clear and objective requirements for HVDC System Owners, DC-connected Power Park Module Owners, Network Operators and National Regulatory Authorities in order to contribute to non-discrimination, effective competition and the efficient functioning of the internal electricity market and to ensure system security.
- (4) The technical connection requirements for HVDC Systems refer unless stated otherwise to the AC Connection Points of such systems, and do not address internal DC connection requirements for multi-terminal or meshed systems.
- (5) In cases where studies for new HVDC System connections require data and models from other grid users such as large generators, industrial facilities and other DC links, this Network Code allows for the Relevant Network Operator to require such information where reasonable. These studies aim at ensuring adequate power quality performance for all grid users.

- (6) This Network Code has been drafted in accordance with the Article 8(7) of Regulation (EC) N°714/2009 according to which the Network Codes shall be developed for cross-border issues and market integration issues and shall be without prejudice to the right of Member States to establish national network codes which do not affect cross-border trade.
- (7) The Network Code provides for various requirements to be defined by the Relevant Network Operators. In those countries where the Transmission System Operators are entitled to define – read here to propose to the relevant bodies for its approval – the technical and instrumental operational procedures for the proper technical management of the power system or to give the necessary instructions to other entities, which need to be taken into account to ensure the necessary coordination of the system and maintain the overall system security, the Network Code does not affect the Transmission System Operators’ competences and responsibilities.
- (8) The Network Code provides for agreements by Relevant Network Operators on various technical requirements. In those countries where the Transmission System Operators are granted public authority or competence to adopt decisions when defining requirements for connecting Power Generating Modules which have to be taken into account for, and cannot be changed by, any subsequent Connection Agreement with the Relevant Network Operator, this Network Code does not affect the Transmission System Operators’ decision making powers in those countries.

HAS ADOPTED THIS NETWORK CODE:

**CONTENTS**

- CHAPTER 1 GENERAL PROVISIONS ..... 8
  - Article 1 Subject matter ..... 8
  - Article 2 Definitions ..... 8
  - Article 3 Scope ..... 10
  - Article 4 Regulatory aspects ..... 14
  - Article 5 Recovery of costs..... 14
  - Article 6 Confidentiality obligations ..... 15
- CHAPTER 2 GENERAL REQUIREMENTS FOR HVDC CONNECTIONS ..... 16
  - SECTION 1 REQUIREMENTS FOR ACTIVE POWER CONTROL AND FREQUENCY SUPPORT..... 16
    - Article 7 Frequency ranges ..... 16
    - Article 8 Rate-of-change-of-Frequency withstand capability..... 17
    - Article 9 Active Power controllability, control range and ramping rate..... 17
    - Article 10 Synthetic inertia ..... 18
    - Article 11 Frequency Sensitive Mode (FSM)..... 19
    - Article 12 Limited Frequency Sensitive Mode Overfrequency (LFSM-O) ..... 21
    - Article 13 Limited Frequency Sensitive Mode Underfrequency (LFSM-U) ..... 22
    - Article 14 Frequency Control ..... 23
    - Article 15 Maximum loss of active power ..... 24
  - SECTION 2 REQUIREMENTS FOR REACTIVE POWER CONTROL AND VOLTAGE SUPPORT ..... 24
    - Article 16 Voltage ranges..... 24
    - Article 17 Short circuit contribution during faults ..... 25
    - Article 18 Reactive Power capability ..... 26
    - Article 19 Reactive Power exchanged with the Network ..... 27
    - Article 20 Reactive Power control mode ..... 28
    - Article 21 Priority to Active or Reactive Power contribution ..... 29
    - Article 22 Power quality..... 29
  - SECTION 3 REQUIREMENTS FOR FAULT RIDE THROUGH..... 29
    - Article 23 Fault ride through capability ..... 29
    - Article 24 Post fault Active Power recovery ..... 31
      - Fast recovery of DC faults..... 31
    - Article 25..... 31
  - SECTION 4 REQUIREMENTS FOR CONTROL..... 31

<i>Article 26</i>	<b>Converter energisation and synchronisation</b> .....	31
<i>Article 27</i>	<b>Interaction between HVDC System(s) and/or other plant(s) and equipment</b> .....	32
<i>Article 28</i>	<b>Power oscillation damping capability</b> .....	32
<i>Article 29</i>	<b>Sub-synchronous torsional interaction damping capability</b> .....	32
<i>Article 30</i>	<b>Network characteristics</b> .....	33
<i>Article 31</i>	<b>HVDC System robustness</b> .....	33
SECTION 5	REQUIREMENTS FOR PROTECTION DEVICES AND SETTINGS .....	34
<i>Article 32</i>	<b>Electrical protection schemes and settings</b> .....	34
<i>Article 33</i>	<b>Priority ranking of protection and control</b> .....	34
<i>Article 34</i>	<b>Changes to protection and control schemes and settings</b> .....	35
SECTION 6	REQUIREMENTS FOR POWER SYSTEM RESTORATION .....	35
<i>Article 35</i>	Black start .....	35
CHAPTER 3	REQUIREMENTS FOR DC-CONNECTED POWER PARK MODULES AND REMOTE-END HVDC CONVERTER STATIONS .....	36
SECTION 1	REQUIREMENTS FOR DC-CONNECTED POWER PARK MODULES .....	36
<i>Article 36</i>	Scope .....	36
<i>Article 37</i>	Frequency stability requirements .....	36
<i>Article 38</i>	Reactive Power and Voltage requirements.....	38
<i>Article 39</i>	Control Requirements .....	41
<i>Article 40</i>	Network characteristics.....	42
<i>Article 41</i>	Protection requirements .....	42
<i>Article 42</i>	Power Quality .....	42
<i>Article 43</i>	General System Management Requirements applicable to DC connected PPMs .....	43
SECTION 2	REQUIREMENTS FOR REMOTE-END HVDC CONVERTER STATIONS .....	43
<i>Article 44</i>	Scope .....	43
<i>Article 45</i>	Frequency stability requirements .....	43
<i>Article 46</i>	Reactive Power and Voltage requirements.....	43
<i>Article 47</i>	Control Requirements .....	45
<i>Article 48</i>	Network characteristics.....	46
<i>Article 49</i>	Power Quality .....	46
CHAPTER 4	INFORMATION EXCHANGE AND COORDINATION .....	47
<i>Article 50</i>	Operation .....	47
<i>Article 51</i>	Parameter setting.....	48
<i>Article 52</i>	Fault recording and Monitoring .....	48

Article 53	Simulation models.....	49
CHAPTER 5	OPERATIONAL NOTIFICATION PROCEDURE FOR CONNECTION.....	50
Article 54	General provisions.....	50
Article 55	Energisation Operational Notification (EON) for HVDC Systems.....	50
Article 56	Interim Operational Notification (ION) for HVDC Systems.....	50
	Final Operational Notification (FON) for HVDC Systems.....	51
Article 57.....		51
Article 58	Limited Operational Notification (LON) for HVDC Systems.....	52
Article 59	General provisions.....	53
Article 60	Energisation Operational Notification (EON) for DC-connected Power Park Modules.....	53
Article 61	Interim Operational Notification (ION) for DC-connected Power Park Modules.....	53
Article 62	Final Operational Notification (FON) for DC-connected Power Park Modules.....	54
Article 63	Limited Operational Notification (LON) for DC-connected Power Park Modules.....	55
Article 64	General provisions.....	55
Article 65	General provisions.....	57
CHAPTER 6	COMPLIANCE.....	60
Article 66	Responsibility of the HVDC System Owner and DC-connected Power Park Module Owner.....	60
Article 67	Tasks of the Relevant Network Operator.....	60
Article 68	Compliance testing for HVDC Systems.....	62
Article 69	Compliance testing for DC-connected Power Park Modules and Remote-end HVDC Converter Units.....	65
Article 70	Compliance simulations for HVDC Systems.....	68
Article 71	Compliance simulations for DC-connected Power Park Modules and Remote-end HVDC Converter Units.....	70
CHAPTER 7	DEROGATIONS.....	72
Article 72	General Provisions.....	72
Article 73	Request for Derogation.....	72
Article 74	Decision on Derogation.....	73
Article 75	Compliance of Existing HVDC Systems and Existing DC-connected Power Park Modules.....	75
Article 76	Register of derogations to the Network Code.....	75
CHAPTER 8	FINAL PROVISIONS.....	77
Article 77	Amendment of contracts and general terms and conditions.....	77
Article 78	Entry into force.....	77

DRAFT

## CHAPTER 1 GENERAL PROVISIONS

### *Article 1*

#### **Subject matter**

1. This Network Code establishes common rules for HVDC Systems and DC-connected Power Park Modules as categorized in Article 3.
2. This Network Code sets up a common framework for Connection Agreements between Network Operators and HVDC System Owners, and between Network Operators and DC-connected Power Park Module Owners.
3. The connection requirements for HVDC Systems as stated in CHAPTER 2 refer, unless stated otherwise, to the AC Connection Point[s] of such systems.
4. The connection requirements for DC-connected Power Park Modules and Remote-end HVDC Converter Stations as stated in CHAPTER 3 refer, unless stated otherwise, to the Interface Point of such systems.
5. In Member States where more than one transmission system operator exists, this regulation shall apply to all transmission system operators within that Member State. Where a transmission system operator does not have a function relevant to one or some obligations under this Network Code, Member States may under the national regulatory regime provide that the responsibility to comply with one or some obligations under this Network Code is assigned to one or more different transmission system operators. In case of such assignment, the Network Code shall apply accordingly to the transmission system operator(s) to which responsibility have been assigned.

### *Article 2*

#### **Definitions**

1. For the purpose of this Network Code, the definitions in Article 2 of Regulation (EC) N° 714/2009, Commission Regulations establishing Network Codes that have been adopted according to Article 6(11) of Regulation (EC) N°714/2009, as well as Article 2 of directive 2009/72/EC shall apply.

2. Furthermore, the following definitions shall apply:

**DC-connected Power Park Module** means a Power Park Module that is connected via an Interface Point to a HVDC System(s). Unless otherwise stated, Power Park Module referred to in this network code means a DC-connected Power Park Module;

**DC-connected Power Park Module Owner** means a natural or legal entity owning a DC-connected Power Park Module;

**Embedded HVDC System** means a HVDC System connected within a Synchronous Area that is not installed for the purpose of connecting a DC-connected Power Park Module at the time of installation, nor installed for the purpose of connecting a Demand Facility;



**Existing HVDC System** means an HVDC System which is not a New HVDC System;

**Existing DC-connected Power Park Module** means a DC-connected Power Park Module which is not a New DC-connected Power Park Module;

**Grid User** means the persons using the transmission or distribution system, as identified in the relevant Network Code requirement. The term means any person (other than the Relevant Network Operator or Relevant TSO) to whom the requirement applies.

**HVDC System Maximum Current** means the highest phase Current, associated with an operating point inside the U-Q/P<sub>max</sub>-profile of the HVDC Converter Station at Maximum HVDC Active Power Transmission Capacity.

**HVDC Converter Station** means part of an HVDC System which consists of one or more HVDC Converter Units installed in a single location together with buildings, reactors, filters, reactive power devices, control, monitoring, protective, measuring and auxiliary equipment;

**HVDC Converter Unit** means a unit comprising one or more converter bridges, together with one or more converter transformers, reactors, converter unit control equipment, essential protective and switching devices and auxiliaries, if any, used for the conversion;

**HVDC System** means an electrical power system which transfers energy in the form of high-voltage direct current between two or more AC buses. A HVDC System comprises of at least two HVDC Converter Stations with DC transmission lines or cables between the HVDC Converter Stations. A back-to-back system is an exception where the HVDC System comprises one HVDC Converter Station with direct DC circuit connection between the pair of HVDC Converter Units. A HVDC System has at least two points of connection; it can connect between two Synchronous Areas, within one Synchronous Area, or between a Power Park Module and a Synchronous Area;

**HVDC System Owner** means a natural or legal entity owning or developing a HVDC System;

**Interface Point** means an AC point in a Network connecting equipment owned by two or more parties (which can be the owner of a Power Generating Module, Demand Facility, Distribution Network or HVDC System) at which technical specifications affecting the performance of the equipment of one or more parties can be prescribed;

**Maximum HVDC Active Power Transmission Capacity** means the maximum continuous Active Power which an HVDC System can exchange with the Network at each Connection Point as defined in the Connection Agreement or as agreed between the Relevant Network Operator and the HVDC System Owner. It is also referred to in this Network Code as  $P_{max}$ .

**Minimum HVDC Active Power Transmission Capacity** means the minimum continuous Active Power which an HVDC System can exchange with the Network at each Connection Point as defined in the Connection Agreement or as agreed between the Relevant Network Operator and the HVDC System Owner. It is also referred to in this Network Code as  $P_{min}$ .

**New HVDC System** means a HVDC System for which

- with regard to the provisions of the initial version of this Network code, a final and binding contract of purchase of the main plant has been signed after the day, which is two years after the day of the entry into force of this Network Code, or,
- with regard to the provisions of the initial version of this Network code, no confirmation is provided by the HVDC System Owner, with a delay not exceeding thirty months as from the day of entry into force of this Network Code, that a final and binding contract of purchase of the main plant exists prior to the day, which is two years after the day of the entry into force of this Network Code, or,
- with regard to the provisions of any subsequent amendment to this Network Code, a final and binding contract of purchase of the main plant has been signed after the day, which is two years after the entry into force of any subsequent amendment to this Network Code;

**New DC-connected Power Park Module** means a DC-connected Power Park Module for which

- with regard to the provisions of the initial version of this Network code, a final and binding contract of purchase of the main plant has been signed after the day, which is two years after the day of the entry into force of this Network Code, or,
- with regard to the provisions of the initial version of this Network code, no confirmation is provided by the DC-connected Power Park Module Owner, with a delay not exceeding thirty months as from the day of entry into force of this Network Code, that a final and binding contract of purchase of the main plant exists prior to the day, which is two years after the day of the entry into force of this Network Code, or,
- with regard to the provisions of any subsequent amendment to this Network Code, a final and binding contract of purchase of the main plant has been signed after the day, which is two years after the entry into force of any subsequent amendment to this Network Code;

**Remote-end HVDC Converter Station** means a HVDC Converter Station which is synchronously connected via an Interface Point to DC-connected Power Park Module(s);

**Remote-end HVDC Converter Station Owner** means a natural or legal entity owning a Remote-end HVDC Converter Station.

### *Article 3*   **Scope**

1. HVDC Systems which are categorized as follows, are within the scope of this Network Code:
  - (a) HVDC Systems connecting Synchronous Areas or Control Areas, including back to back schemes;
  - (b) HVDC Systems connecting Power Park Modules to a Transmission Network or a Distribution Network;
  - (c) Embedded HVDC Systems within one Control Area and connected to the Transmission Network; and

- (d) Embedded HVDC Systems within one Control Area and connected to the Distribution Network when a cross-border impact is demonstrated by the Relevant TSO, while respecting the provisions of Article 4(3). The Relevant TSO shall consider the long-term development of the Network in this assessment.
2. The application of this Network Code for Power Park Modules connected to a Transmission Network or Distribution Network which is not part of a Synchronous Area shall be defined by the Relevant Network Operator in coordination with the Relevant TSO, while respecting the provisions of Article 4(3). All other Power Park Modules which are AC collected but are DC connected to a Synchronous Area are within the scope of this Network Code.
  3. Article 22, Article 27 and Article 29, addressing contribution of data and studies, apply to Existing Power Generating Modules, Existing Distribution Networks, Existing Demand Facilities and Existing HVDC Systems.
  4. With regards to the Embedded HVDC Systems within one Control Area referred to in paragraphs 1(c) and (d) above, when they fall into one of the categories listed below:
    - i. HVDC Systems with at least one HVDC Converter Station owned by the Relevant TSO;
    - ii. HVDC Systems owned by an entity which exercises control over the Relevant TSO; or
    - iii. HVDC Systems owned by an entity directly or indirectly controlled by an entity which also exercises control over the Relevant TSO,the following shall apply:
    - a. The provisions of Article 54 to Article 58, Article 65 to Article 71, and Article 77 do not apply; and
    - b. The HVDC System Owner shall ensure that the HVDC System is compliant with the requirements under Article 7 to Article 35, Article 50 and Article 52 of this Network Code. This compliance shall be maintained throughout the lifetime of the facility.
  5. The requirements set forth by this Network Code shall apply to New HVDC Systems and New DC-connected Power Park Modules in a Member State
  6. In addition to the requirements referred to in Article 3(3), other requirements set forth in this Network Code shall apply to Existing HVDC Systems and Existing DC-connected Power Park Modules which are deemed significant according to the provisions of this Network Code to the extent this has been decided by the Relevant National Regulatory Authority pursuant to Article 64 and Article 65.
  7. With regard to HVDC Systems not yet connected to the Network:
    - (a) Within a delay not exceeding thirty months as from the day of entry into force of this Network Code, the HVDC System Owner shall provide the Relevant TSO with a confirmation of final and binding contracts it has concluded for the construction,

assembly or purchase of the main plant of a HVDC System with relevance to the provisions of this Network Code and which exists prior to the day, which is two years after the day of entry into force of this Network Code.

- (b) The confirmation shall at least indicate the contract title, its date of signature and of entry into force, and the specifications of the main plant to be constructed, assembled or purchased.
  - (c) The Relevant TSO may demand that the National Regulatory Authority confirms the existence, relevance and finality of such a contract, i.e. that its material terms can no longer be changed by one of the parties to the contract unilaterally and that no party to the contract has the right to terminate it at will. The HVDC System Owner shall supply the National Regulatory Authority with all documents the National Regulatory Authority requests in order to ascertain that a binding and final contract exists.
  - (d) The HVDC System shall be considered as an Existing HVDC System, provided that:
    - i. In accordance with Article 3(7) (a) and (b) above, the Relevant TSO is provided with sufficient evidence of the existence of binding and final contracts for the construction, assembly or purchase of the main plant of a HVDC System prior to the day, which is two years after the day of entry into force of this Network Code; or
    - ii. Following the verification performed by the National Regulatory Authority in accordance with Article 3(7) (c), it is ascertained that binding and final contracts for the construction, assembly or purchase of the main plant of a HVDC System exist prior to the day, which is two years after the day of entry into force of this Network Code.
  - (e) In case the HVDC System Owner does not provide the Relevant TSO with the confirmation within the delay set forth in Article 3(7) (a), the HVDC System shall be considered as a New HVDC System.
8. With regard to DC-connected Power Park Modules not yet connected to the Network:
- (a) Within a delay not exceeding thirty months as from the day of entry into force of this Network Code, the DC-connected Power Park Module Owner shall provide the Relevant TSO with a confirmation of final and binding contracts it has concluded for the construction, assembly or purchase of the main plant of the DC-connected Power Park Module and/or the HVDC System (when the HVDC System Owner is the same as the DC-connected Power Park Module Owner and is built as part of the development of the DC-connected Power Park Module) with relevance to the provisions of this Network Code and which exists prior to the day, which is two years after the day of entry into force of this Network Code.
  - (b) The confirmation shall at least indicate the contract title, its date of signature and of entry into force, and the specifications of the main plant to be constructed, assembled or purchased.
  - (c) The Relevant TSO may demand that the National Regulatory Authority confirms the existence, relevance and finality of such a contract, i.e. that its material terms can no longer be changed by one of the parties to the contract unilaterally and that no party to the contract has the right to terminate it at will. The DC-connected Power Park Module Owner shall supply the National Regulatory Authority with all documents the

National Regulatory Authority requests in order to ascertain that a binding and final contract exists.

- (d) The DC-connected Power Park Module shall be considered as an Existing DC-connected Power Park Module, provided that:
  - i. In accordance with Article 3(8)(a) and (b) above, the Relevant TSO is provided with sufficient evidence of the existence of binding and final contracts for the construction, assembly or purchase of the main plant of a DC-connected Power Park Module and/or where applicable the HVDC System prior to the day, which is two years after the day of entry into force of this Network Code; or
  - ii. Following the verification performed by the National Regulatory Authority in accordance with Article 3(8)(c), it is ascertained that binding and final contracts for the construction, assembly or purchase of the main plant of a DC-connected Power Park Module and where applicable the HVDC System exist prior to the day, which is two years after the day of entry into force of this Network Code.
- (e) In case the DC-connected Power Park Module Owner does not provide the Relevant TSO with the confirmation within the delay set forth in Article 3(8)(a), the DC-connected Power Park Module and as applicable HVDC System shall be considered as a New DC-connected Power Park Module and/or HVDC System.

- 9. All HVDC Systems, HVDC Converter Stations and DC-connected Power Park Modules, existing and new, shall fulfil the following requirements related to equipment development, modernisation and replacement:
  - a) An HVDC System Owner or DC-connected Power Park Module Owner intending to develop, modernise or replace a part of a HVDC System, HVDC Converter Station, HVDC Converter Unit or DC-connected Power Park Module in a way that may have an impact on its performance and ability to meet the requirements of this Network Code shall notify the Relevant Network Operator(s). The notification shall take place in advance and in accordance with national timescales defined, while respecting the provisions of Article 4(3).
  - b) The HVDC System Owner or DC-connected Power Park Module shall, while respecting the provisions of Article 4(3), agree with the Relevant Network Operator on these requirements before the proposals are implemented. In case of modernisation or replacement of equipment in existing or new HVDC Systems, HVDC Converter Stations and DC-connected Power Park Modules. The equipment shall comply with the requirements which are relevant to the planned work.
  - c) While respecting the provisions of Article 4(3), the use of existing spare components for the purpose of development and modernization that do not comply with the requirements has to be agreed with the Relevant Network Operator in each case.

*Article 4*

**Regulatory aspects**

1. The requirements established in this Network Code and their applications are based on the principle of non-discrimination and transparency as well as the principle of optimisation between the highest overall efficiency and lowest total cost for all involved parties.
2. Notwithstanding the above, the application of non-discrimination principle and the principle of optimization between the highest overall efficiency and lowest total costs for all involved parties shall be balanced with the aim of achieving the maximum transparency in issues of interest for the market and the assignment to the real originator of the costs.
3. Where reference is made to this paragraph, the terms and conditions for connection and access to networks or their methodologies shall be established by the National Regulatory Authorities, or by the Member States in accordance with the rules of national law implementing Directive 2009/72/EC, and with the principles of transparency, proportionality and non-discrimination.
4. Any decision by a Network Operator other than the Relevant TSO and any agreement between a Network Operator other than the Relevant TSO and either a DC-connected Power Park Module Owner or a HVDC System Owner shall be exercised in compliance with and respecting the Relevant TSO's responsibility to ensure system security according to national legislation. Further details to ensure this principle may be specified either by national legislation, or by agreements between the Relevant TSO and the Network Operators in its Control Area, as the case may be.
5. The allocation of tasks between the Relevant Network Operators, as well as the legal framework under which they determine the grid connection requirements under this Network Code, are established pursuant to this Network Code. TSO(s) granted public authority or competence according to national law can adopt decisions when defining requirements under this Network Code while respecting Directive 2009/72/EC.
6. Any decision or agreement adopted pursuant to this Network Code and affecting more than one Member State shall be coordinated among the concerned TSOs and NRAs.

*Article 5*

**Recovery of costs**

1. The costs related to the obligations referred to in this Network Code which have to be borne by regulated Network Operators shall be assessed by National Regulatory Authorities.
2. Costs assessed as efficient, reasonable and proportionate shall be recovered as determined by National Regulatory Authorities.
3. If requested by National Regulatory Authorities, regulated Network Operators shall, within three months of such a request, use best endeavours to provide such additional information as reasonably requested by National Regulatory Authorities to facilitate the assessment of the costs incurred.

*Article 6*

**Confidentiality obligations**

1. Each Relevant TSO, DSO, HVDC System Owner or DC-connected Power Park Module Owner shall preserve the confidentiality of the information and data submitted to them in connection with this Network Code and shall use them exclusively for the purpose they have been submitted in compliance with the Network Code.
2. Without prejudice to the obligation to preserve the confidentiality of commercially sensitive information obtained in the course of carrying out its activities, each TSO shall provide to the operator of any other transmission system with which its system is interconnected, sufficient information to ensure the secure and efficient operation, coordinated development and interoperability of the interconnected system.
3. In case of disclosure for other purposes than those described in Article 6(1) and/or 6(2), a Relevant Network Operator shall seek the consent of the owner of such information and data. This consent shall not be unreasonably withheld.

## CHAPTER 2 GENERAL REQUIREMENTS FOR HVDC CONNECTIONS

### SECTION 1 REQUIREMENTS FOR ACTIVE POWER CONTROL AND FREQUENCY SUPPORT

#### *Article 7*    **Frequency ranges**

1. A HVDC System shall fulfil the following requirements referring to Frequency stability:
  - (a) An HVDC System shall be capable of staying connected to the Network and remaining operable within the Frequency ranges and time periods specified by Table 1, for the short circuit power range as specified in Article 30(1)b.
  - (b) While respecting the provisions of Article 4(3), wider Frequency ranges or longer minimum times for operation can be agreed between the Relevant TSO and the HVDC System Owner if needed to preserve or to restore system security. If wider Frequency ranges or longer minimum times for operation are economically and technically feasible, the consent of the HVDC System Owner shall not be unreasonably withheld.
  - (c) Notwithstanding Article 7(1)(a) above, a HVDC System shall be capable of automatic disconnection at specified Frequencies.
  - (d) The Relevant TSO shall have the right to specify a maximum admissible Active Power output reduction when operating at Maximum HVDC Active Power Transmission Capacity, if the system Frequency falls below 49 Hz, while respecting the provisions of Article 4(3).



Frequency range	Time period for operation
47.0 Hz – 47.5 Hz	60 seconds
47.5 Hz – 48.5 Hz	To be defined by each Relevant TSO while respecting the provisions of Article 4(3), but longer than defined times for generation and demand according to [NC RfG] and [DCC], respectively, and longer than for DC-connected PPMs according to Article 37
48.5 Hz – 49.0 Hz	To be defined by each Relevant TSO while respecting the provisions of Article 4(3), but longer than defined times for generation and demand according to [NC RfG] and [DCC], respectively, and longer than for DC-connected PPMs according to Article 37
49.0 Hz – 51.0 Hz	Unlimited
51.0 Hz – 51.5 Hz	To be defined by each Relevant TSO while respecting the provisions of Article 4(3), but longer than defined times for generation and demand according to [NC RfG] and [DCC], respectively, and longer than for DC-connected PPMs according to Article 37
51.5 Hz – 52.0 Hz	To be defined by each Relevant TSO while respecting the provisions of Article 4(3) and longer than for DC-connected PPMs according to Article 37

Table 1: This table shows the minimum time periods an HVDC System shall be able to operate for different Frequencies deviating from a nominal value without disconnecting from the Network.

#### *Article 8* **Rate-of-change-of-Frequency withstand capability**

With regard to the rate of change of Frequency withstand capability, a HVDC System shall be capable of staying connected to the Network and operable if the Network Frequency changes at a rate between -2.5 and +2.5 Hz/s (measured at any point in time as an average of the rate of change of Frequency for the previous 1s).

#### *Article 9* **Active Power controllability, control range and ramping rate**

1. With regard to the capability of controlling the transmitted Active Power:
  - (a) The HVDC System shall be capable of adjusting the transmitted Active Power up to the Maximum HVDC Active Power Transmission Capacity of the HVDC System in each direction following an Instruction from the Relevant TSO(s).
    - i. The Relevant TSO(s) shall have the right to specify, while respecting the provisions of Article 4(3), a minimum power step size for adjusting the transmitted Active Power.

- ii. The Relevant TSO(s) shall have the right, while respecting the provisions of Article 4(3) to define a Minimum HVDC Active Power Transmission Capacity for each direction, below which Active Power transmission capability is not requested.
    - iii. A procedure for adjusting the transmitted Active Power shall be agreed between the Relevant TSO(s) and HVDC System Owner, defining in particular the maximum delay within which the HVDC System shall be capable of adjusting the transmitted Active Power upon receipt of request from the Relevant TSO(s).
  - (b) In case of Disturbance in one or more of the connecting AC Networks, the HVDC System shall be capable of modifying the transmitted Active Power in accordance with pre-defined regulation sequences. This shall be achieved as fast as technically feasible with an initial delay as short as possible. If the initial delay prior to the start of the change is greater than 10 milliseconds from receiving the triggering signal sent by the Relevant TSO(s), it shall be reasonably justified by the HVDC System Owner to the Relevant TSO(s).
  - (c) The Relevant TSO(s) shall have the right, while respecting the provisions of Article 4(3) to require the HVDC System to be capable of fast Active Power reversal. The power reversal shall be possible from the Maximum Active Power Transmission Capacity in one direction to the Maximum Active Power Transmission Capacity in the other direction as fast as technically feasible and reasonably justified by the HVDC System Owner to the Relevant TSOs if greater than 2 seconds.
  - (d) For HVDC Systems linking various Control Areas or Synchronous Areas, the HVDC System shall be capable of exchange and performing sharing of Frequency Containment Reserve, Frequency Restoration Reserve and Replacement Reserve, as well as Imbalance Netting Power Interchange in accordance with [NC LFCR].
2. With regard to the capability of controlling ramping rate, the HVDC System shall be capable of adjusting the ramping rate of Active Power variations within its technical capabilities in accordance with Instructions sent by the Relevant TSO(s). In case of modification of Active Power according to Article 9(1) (b) and (c), ramping rate adjustment shall be inhibited.
3. The Relevant TSO shall have the right to require, while respecting the provisions of Article 4(3), in coordination with adjacent TSO(s), that the control functions of a HVDC System shall be capable of taking automatic remedial actions including, but not limited to, stopping the ramping and blocking FSM, LFSM-O, LFSM-U and Frequency control. The triggering and blocking criteria shall be defined by the Relevant TSO(s) and subject to notification to the National Regulatory Authority. The modalities of that notification shall be determined in accordance with the applicable national regulatory framework.

#### *Article 10 Synthetic inertia*

1. With regard to the capability of providing Synthetic Inertia in response to a rate of change of Frequency:
  - (a) The Relevant TSO shall have the right to require that a HVDC System shall be capable of providing Synthetic Inertia as a quantified response to Frequency changes, activated in low and/or high Frequency regimes by rapidly adjusting the Active Power injected to or withdrawn from the AC Network in order to limit the rate of change of Frequency, while

respecting the provisions of Article 4(3) of this Network Code and at least accounting for the results of the studies as specified in Article 15(8)c) of [NC OS].

- (b) The principle of this control system and the associated performance parameters shall be agreed between the Relevant TSO and the HVDC System Owner while respecting the provisions of Article 4(3).

**Article 11 Frequency Sensitive Mode (FSM)**

1. When operating in Frequency Sensitive Mode (FSM), the following shall apply:
  - (a) The HVDC System shall be capable of responding to Frequency deviations in each connected AC Network by adjusting the Active Power transmission as indicated in Figure 1 and in accordance with the parameters specified by each TSO within the ranges shown in Table 2. This specification shall be subject to notification to the National Regulatory Authority. The modalities of that notification shall be determined in accordance with the applicable national regulatory framework.
  - (b) The adjustment of Active Power Frequency Response is limited by the Minimum HVDC Active Power Transmission Capacity and Maximum HVDC Active Power Transmission Capacity of the HVDC System (in each direction).




Figure 1: Active Power Frequency Response capability of a HVDC connection scheme in FSM illustrating the case of zero deadband and insensitivity with a positive Active Power Setpoint.  $\Delta P$  is the change in Active Power output from the HVDC System.  $f_n$  is the target Frequency in the AC Network where the FSM service is provided and  $\Delta f$  is the Frequency deviation in the AC Network where the FSM service is provided.

Parameters	Ranges
Frequency Response Deadband	0 – ±500mHz
Droop $s_1$ (upward regulation)	Minimum 0.1%
Droop $s_2$ (downward regulation)	Minimum 0.1%
Frequency Response Insensitivity	Maximum 30 mHz

Table 2: Parameters for Active Power Frequency Response in FSM

- (c) The HVDC System shall be capable, following an Instruction of the Relevant TSO, of adjusting the Droops for upward and downward regulation, the Frequency Response Deadband and the operational range of variation within the Active Power range available for FSM, defined in Figure 1 and more generally within the limits set by Article 11 (1) (a) and (b). These values shall be subject to notification to the National Regulatory Authority. The modalities of that notification shall be determined in accordance with the applicable national regulatory framework.
- (d) As a result of a Frequency step change, the HVDC System shall be capable of adjusting full Active Power Frequency Response, at or above the solid line according to Figure 2 in accordance with the parameters specified by each Relevant TSO within the ranges according to Table 3:
- i. The HVDC System shall be able to adjust Active Power Output  $\Delta P$  up to the limit of the Active Power range requested by the Relevant TSO in accordance with the times  $t_1$  and  $t_2$  according to the ranges in Table 3, where  $t_1$  is the initial delay and  $t_2$  is the time for full activation. The values of  $t_1$  and  $t_2$  shall be specified by the Relevant TSO, subject to notification to the National Regulatory Authority. The modalities of that notification shall be determined in accordance with the applicable national regulatory framework.
  - ii. The initial delay of activation shall be as short as possible. If greater than 0.5 second, the initial delay of activation shall be reasonably justified by the HVDC System Owner to the Relevant TSO and shall be subject to approval by the Relevant TSO, while respecting the provisions of Article 4(3).
  - iii. The specification of the values of  $t_1$  and  $t_2$  shall be subject to notification to the National Regulatory Authority. The modalities of that notification shall be determined in accordance with the applicable national regulatory framework.




Figure 2: Active Power Frequency Response capability of a HVDC System.  $\Delta P$  is the change in Active Power triggered by the step change in Frequency..

Parameters	Time
Maximum admissible initial delay $t_1$	0.5 seconds
Maximum admissible choice of full activation time $t_2$ , unless longer activation times are admitted by the Relevant TSO for system stability reasons	30 seconds

Table 3: Parameters for full activation of Active Power Frequency Response resulting from Frequency step change.

- (e) For HVDC Systems linking various Control Areas or Synchronous Areas, in Frequency Sensitive Mode operation the HVDC System shall be capable of adjusting full Active Power Frequency Response at any time and for a continuous time period.
- (f) As long as a Frequency deviation continues Active Power control shall not have any adverse impact on the Active Power Frequency Response.

**Article 12 Limited Frequency Sensitive Mode Overfrequency (LFSM-O)**

1. In addition to Article 11 the following shall apply cumulatively with regard to Limited Frequency Sensitive Mode – Overfrequency (LFSM-O):
  - (a) The HVDC System shall be capable of adjusting Active Power exchange with the AC Network(s), during both import and export, according to Figure 3 at a Frequency threshold  $f_1$  between and including 50.2 Hz and 50.5 Hz with a Droop having a minimum value of 0.1 %.

The actual Frequency threshold and Droop settings shall be determined by the Relevant TSO and shall be subject to notification to the National Regulatory Authority. The modalities of that notification shall be determined in accordance with the applicable national regulatory framework. The HVDC System shall be capable of adjusting Active Power Frequency Response as fast as technically feasible with an initial delay that shall be as short as possible. If greater than 0.5 seconds, the delay shall be reasonably justified by the HVDC System Owner to the Relevant TSO and shall be subject to approval by the Relevant TSO, while respecting the provisions of Article 4(3).




Figure 3: Active Power Frequency Response of HVDC Systems in LFSM-O.  $\Delta P$  is the change in Active Power output from the HVDC System, depending on the operation condition a decrease of import power or an increase of export power.  $f_n$  is the nominal Frequency of the AC Network(s) the HVDC System is connected to and  $\Delta f$  is the Frequency change in the AC Network(s) the HVDC is connected to. At overfrequencies where  $f$  is above  $f_1$  the HVDC System shall reduce Active Power according to the Droop setting.

- (b) The HVDC System shall be capable of stable operation during LFSM-O operation. When LFSM-O is active, hierarchy of control functions shall be organised in accordance with Article 33.

#### Article 13 Limited Frequency Sensitive Mode Underfrequency (LFSM-U)

1. In addition to Article 11 the following shall apply cumulatively with regard to Limited Frequency Sensitive Mode – Underfrequency (LFSM-U):
  - (a) The HVDC System shall be capable of adjusting the Active Power Frequency Response to the AC Network(s), during both import and export, according to Figure 4 at a Frequency threshold  $f_2$  between and including 49.8 Hz and 49.5 Hz with a Droop having a minimum value of 0.1 %. In the LFSM-U mode the HVDC System shall be capable of adjusting power up to its Maximum HVDC Active Power Transmission Capacity. The actual Frequency threshold and Droop settings shall be determined by the Relevant TSO and shall be subject to

notification to the National Regulatory Authority. The modalities of that notification shall be determined in accordance with the applicable national regulatory framework. The Active Power Frequency Response shall be activated as fast as technically feasible with an initial delay that shall be as short as possible. If greater than 0.5 second, the delay shall be reasonably justified by the HVDC System Owner to the Relevant TSO and shall be subject to approval by the Relevant TSO, while respecting the provisions of Article 4(3).




Figure 4: Active Power Frequency Response capability of HVDC Systems in LFSM-U.  $\Delta P$  is the change in Active Power output from the HVDC System, depending on the operation condition a decrease of import power or an increase of export power.  $f_n$  is the nominal Frequency in the AC Network(s) the HVDC System is connected and  $\Delta f$  is the Frequency change in the AC Network(s) the HVDC is connected. At underfrequencies where  $f$  is below  $f_2$ , the HVDC System has to increase Active Power output according to the Droop  $s$ .

- (b) The HVDC System shall be capable of stable operation during LFSM-U operation. When LFSM-U is active, hierarchy of control functions shall be organised in accordance with Article 33.

#### Article 14 Frequency Control

1. With regard to the capability of providing additional Frequency Control to those defined in Articles 11, 12 and 13:
  - (a) The Relevant TSO(s) shall have the right to require, while respecting the provisions of Article 4(3), that a HVDC System shall be equipped with an independent control mode to modulate the Active Power output of the HVDC Converter Station depending on the Frequencies at all Connection Points of the HVDC System in order to maintain stable system Frequencies.
  - (b) The operating principle, the associated performance parameters and the activation criteria of this Frequency Control shall be defined by the Relevant TSO(s) while respecting the provisions of Article 4(3).

Article 15 **Maximum loss of active power**

1. The HVDC System shall be configured such that its loss of Active Power injection in a Synchronous Area, arising out of a transient or permanent fault, shall be limited to a value defined by the Relevant TSOs for their respective LFC Block, while respecting the provisions of Article 4(3).
2. Where the HVDC System connects two or more LFC Blocks, the Relevant TSOs shall consult each other in order to set a coordinated value of the maximum loss of Active Power injection as referred to in Article 15(1) above, taking into account common mode failures.

**SECTION 2**  
**REQUIREMENTS FOR REACTIVE POWER CONTROL AND VOLTAGE SUPPORT**

Article 16 **Voltage ranges**

1. HVDC Converter Stations shall be capable of fulfilling the following requirements with regard to steady state Voltage ranges:
  - (a) Notwithstanding the provisions of Article 23, a HVDC Converter Station shall be capable of staying connected to the Network and capable of operating at HVDC System Maximum Current, within the ranges of the Network Voltage at the Connection Point, expressed by the Voltage at the Connection Point related to nominal Voltage (per unit), and the time periods specified by Table 4 or Table 5. The establishment of the reference nominal Voltage shall be subject to coordination between the adjacent Relevant Network Operator(s), while respecting the provisions of Article 4(3).

<i>Synchronous Area</i>	<i>Voltage Range</i>	<i>Time period for operation</i>
<b>Continental Europe</b>	0.85 pu – 1.118 pu	Unlimited
	1.118 pu – 1.15 pu	To be defined by each TSO while respecting the provisions of Article 4(3), but not less than 20 minutes
<b>Nordic</b>	0.90 pu – 1.05 pu	Unlimited
	1.05 pu – 1.10 pu	60 minutes
<b>Great Britain</b>	0.90 pu – 1.10 pu	Unlimited
<b>Ireland</b>	0.90 pu – 1.118 pu	Unlimited
<b>Baltic</b>	0.85 pu – 1.12 pu	Unlimited
	1.12 pu – 1.15 pu	20 minutes

Table 4: This table shows the minimum time periods a HVDC System shall be capable of operating for Voltages deviating from the nominal system value at the Connection Point(s) without disconnecting from the Network. This table applies in case of pu Voltage base values below 300 kV.

Synchronous Area	Voltage Range	Time period for operation
Continental Europe	0.85 pu – 1.05 pu	Unlimited



	1.05 pu – 1.0875 pu	To be decided by each TSO while respecting the provisions of Article 4(3), but not less than 60 minutes
	1.0875 pu – 1.10 pu	60 minutes
Nordic	0.90 pu – 1.05 pu	Unlimited
	1.05 pu – 1.10 pu	60 minutes
Great Britain	0.90 pu – 1.05 pu	Unlimited
	1.05 pu – 1.10 pu	15 minutes
Ireland	0.90 pu – 1.05 pu	Unlimited
Baltic	0.88 pu – 1.10 pu	Unlimited
	1.10 pu – 1.15 pu	20 minutes

Table 5: This table shows the minimum time periods a HVDC System shall be capable of operating for Voltages deviating from the nominal system value at the Connection Point(s) without disconnecting from the Network. This table applies in case of pu Voltage base values from 300 kV to 400 kV (included).

- (b) While respecting the provisions of Article 4(3), wider Voltage ranges or longer minimum times for operation can be agreed between the Relevant Network Operator in coordination with the Relevant TSO and the HVDC System Owner to ensure the best use of the technical capabilities of a HVDC System if needed to preserve or to restore system security. If wider Voltage ranges or longer minimum times for operation are economically and technically feasible, the consent of the HVDC System Owner shall not be unreasonably withheld.
- (c) The Relevant Network Operator, in coordination with the Relevant TSO, shall have the right to specify, while respecting the provisions of Article 4(3), Voltages at the Connection Point at which a HVDC Converter Station shall be capable of automatic disconnection. The terms and settings for automatic disconnection shall be agreed between the Relevant Network Operator in coordination with the Relevant TSO and the HVDC System Owner, while respecting the provisions of Article 4(3).
- (d) For Connection Point(s) at nominal AC Voltages that are not included in the scope of Table 4 and Table 5, the Relevant Network Operator in coordination with the Relevant TSO(s) shall define applicable requirements at the Connection Point(s), while respecting the provisions of Article 4(3).

#### Article 17 Short circuit contribution during faults

1. HVDC Systems shall fulfil the following requirement referring to Voltage stability:
  - (a) The Relevant Network Operator in coordination with the Relevant TSO shall have the right to require while respecting the provisions of Article 4(3) the capability of a HVDC System to provide Fast Fault Current at a specific Connection Point in case of symmetrical (3-phase) faults.
  - (b) The Relevant Network Operator in coordination with the Relevant TSO shall while respecting the provisions of Article 4(3) specify
    - how and when a Voltage deviation is to be determined as well as the end of the Voltage deviation,
    - the characteristics of the Fast Fault Current,

- the timing and accuracy of the Fast Fault Current, which may include several stages.
- (c) With regard to the supply of Fast Fault Current in case of asymmetrical (1-phase or 2-phase) faults the Relevant Network Operator in coordination the Relevant TSO shall have the right to introduce while respecting the provisions of Article 4(3) a requirement for asymmetrical current injection.

#### *Article 18* **Reactive Power capability**

1. The HVDC Converter Station shall fulfil the following requirements referring to Voltage stability, at the Connection Point(s):
- (a) The Relevant Network Operator in coordination with the Relevant TSO(s) shall define while respecting the provisions of Article 4(3) the Reactive Power capability requirements in the context of varying Voltage. In doing so, it shall define a U-Q/Pmax-profile, within the boundary of which the HVDC Converter Station shall be capable of providing Reactive Power at its Maximum HVDC Active Power Transmission Capacity.
  - (b) The U-Q/Pmax-profile shall be defined by the Relevant Network Operator in coordination with the Relevant TSO(s) while respecting the provisions of Article 4(3) in conformity with the following principles:
    - the U-Q/Pmax-profile shall not exceed the U-Q/Pmax-profile envelope represented by the inner envelope in Figure 5, and does not need to be rectangular.
    - the dimensions of the U-Q/Pmax-profile envelope shall respect the values defined for each Synchronous Area in Table 6; and
    - the position of the U-Q/Pmax-profile envelope shall lie within the limits of the fixed outer envelope in Figure 5.
  - (c) The HVDC System shall be capable of moving to any operating point within its U-Q/Pmax profile in timescales requested by the Relevant Network Operator in coordination with the Relevant TSO, while respecting the provisions of Article 4(3).
  - (d) When operating at an Active Power output below the Maximum HVDC Active Power Transmission Capacity ( $P < P_{max}$ ), the HVDC Converter Station shall be capable of operating in every possible operating point, as defined by the Relevant Network Operator in coordination with the Relevant TSO, while respecting the provisions of Article 4(3), and in accordance with the Reactive Power capability defined by the U-Q/Pmax profile specified in Article 18(1) paragraphs (a),(b) and (c) above.




Figure 5: The diagram represents boundaries of a U-Q/Pmax-profile with U being the Voltage at the Connection Point expressed by the ratio of its actual value to its nominal value in per unit, and Q/Pmax the ratio of the Reactive Power to the Maximum HVDC Active Power Transmission Capacity. The position, size and shape of the inner envelope are indicative and shapes other than rectangular may be used within the inner envelope. For profile shapes other than rectangular, the Voltage range represents the highest and lowest Voltage points in this shape. Such a profile would not give rise to the full Reactive Power range being available across the range of steady-state Voltages;

Synchronous Area	Maximum range of Q/Pmax	Maximum range of steady-state Voltage level in PU
Continental Europe	0.95	0.225
Nordic	0.95	0.150
Great Britain	0.95	0.100
Ireland	1.08	0.218
Baltic States	1.0	0.220

Table 6: Parameters for the Inner Envelope in Figure 5

**Article 19 Reactive Power exchanged with the Network**

1. The HVDC System Owner shall ensure that the Reactive Power of its HVDC Converter Station exchanged with the Network at the Connection Point is limited to values defined by the Relevant Network Operator in coordination with the Relevant TSO(s), while respecting the provisions of Article 4(3).
2. The Reactive Power variation caused by the Reactive power control mode operation of the HVDC Converter Station, as listed in Article 20(1), shall not result in a Voltage step exceeding the allowed value at the Connection Point. This maximum tolerable Voltage step value shall be specified by the Relevant Network Operator in coordination with the Relevant TSO, while respecting the provisions of Article 4(3).

*Article 20* **Reactive Power control mode**

1. Each HVDC Converter Station shall as a minimum be capable of operating in two out of the three following control modes, as specified by the Relevant Network Operator in coordination with the Relevant TSO:
  - (a) Voltage Control mode;
  - (b) Reactive Power control mode;
  - (c) Power Factor control mode;
2. The Relevant Network Operator in coordination with the Relevant TSO shall have the right to require other control mode capabilities, while respecting the provision of Article 4(3).
3. For the purposes of Voltage control mode, each HVDC Converter Station shall be capable of contributing to Voltage control at the Connection Point utilising its capabilities, while respecting the provisions of Articles 18 and 19, in accordance with the following control characteristics:
  - (a) A Setpoint Voltage at the Connection Point shall be specified to cover a specific operation range, either continuously or in steps, as defined by the Relevant Network Operator in coordination with the Relevant TSO , while respecting the provisions of Article 4(3);
  - (b) The Voltage control may be operated with or without a deadband around the Setpoint selectable in a range from zero to +/-5 % of nominal Network Voltage. The dead band shall be adjustable in steps as specified by the Relevant Network Operator, while respecting the provisions of Article 4(3).
  - (c) Following a step change in Voltage, the HVDC Converter Station shall be capable of
    - i. achieving 90 % of the change in Reactive Power output within a time  $t_1$ , to be specified by the Relevant Network Operator, while respecting the provisions of Article 4(3) in the range of 0.1 - 5 seconds; and
    - ii. settling at the value defined by the operating Slope within a time  $t_2$ , to be specified by the Relevant Network Operator, while respecting the provisions of Article 4(3), in the range of 1 - 60 seconds, with a specified steady-state tolerance given in % of the maximum Reactive Power.
  - (d) Voltage control mode shall include the capability to change Reactive Power output based on a combination of a modified Setpoint Voltage and an additional instructed Reactive Power component. The Slope shall be specified by a range and step defined by the Relevant Network Operator in coordination with the Relevant TSO , while respecting the provisions of Article 4(3).
4. With regard to Reactive Power control mode, the Relevant Network Operator shall specify, while respecting the provisions of Article 4(3), a Reactive Power range in Mvar or in % of maximum Reactive Power, as well as its associated accuracy at the Connection Point, utilising the capabilities of the HVDC system, while respecting the provisions of Articles 18 and 19.
5. For the purposes of Power Factor control mode, the HVDC Converter Station shall be capable of controlling the Power Factor to a target at the Connection Point, while respecting the provisions

of Articles 18 and 19. The available target values shall be available in steps no greater than a maximum allowed step specified by the Relevant Network Operator, while respecting the provisions of Article 4(3).

6. The Relevant Network Operator in coordination with the Relevant TSO shall define, while respecting the provisions of Article 4(3), any equipment needed to enable the remote selection of control modes and relevant Setpoint(s).

#### **Article 21 Priority to Active or Reactive Power contribution**

The Relevant TSO(s) shall assess, while respecting the provisions of Article 4(3), and utilizing the capabilities of the HVDC System defined according to this Network Code, whether Active Power contribution or Reactive Power contribution shall have priority during low or high Voltage operation and during faults for which fault-ride-through capability is required. If priority is given to Active Power contribution, its provision shall be established within a time from the fault inception as defined by Relevant TSO while respecting the provisions of Article 4(3).

#### **Article 22 Power quality**

An HVDC System Owner shall ensure that its HVDC System connection to the Network does not result in a level of distortion or fluctuation of the supply Voltage on the Network, at the Connection Point(s), exceeding the level allocated to them by the Relevant Network Operator in coordination with the Relevant TSO, while respecting the provisions of Article 4(3). The process for necessary studies to be conducted and relevant data to be provided by all Grid Users involved, as well as mitigating actions identified and implemented shall be in accordance with the process in Article 27.

### **SECTION 3 REQUIREMENTS FOR FAULT RIDE THROUGH**

#### **Article 23 Fault ride through capability**

1. With regard to fault-ride-through capability of a HVDC System:
  - (a) The Relevant TSO shall define, while respecting the provisions of Article 4(3), a Voltage-against-time-profile according to Figure 6 and Table 7 at the Connection Point(s) for fault conditions, under which the HVDC Converter Station shall be capable of staying connected to the Network and continuing stable operation after the power system has recovered following fault clearance. This Voltage-against-Time-profile shall be expressed by a lower limit of the course of the phase-to-phase Voltages on the Network Voltage level at the Connection Point(s) during a symmetrical fault, as a function of time before, during and after the fault.
  - (b) The Relevant Network Operator shall provide on request by the HVDC System Owner the pre-fault and post-fault conditions as defined in Article 30 regarding:
    - pre-fault minimum short circuit capacity at the Connection Point(s) expressed in MVA;

- pre-fault operating point of the HVDC Converter Station expressed in Active Power output and Reactive Power output, and the operating Voltage at the Connection Point[s];
- post-fault minimum short circuit capacity at the Connection Point(s) expressed in MVA.

Alternatively, generic values for the above conditions derived from typical cases may be provided by the Relevant Network Operator.




Figure 6: Fault-ride-through profile of a HVDC Converter Station. The diagram represents the lower limit of a Voltage-against-time profile at the Connection Point, expressed by the ratio of its actual value and its nominal value in per unit before, during and after a fault.  $U_{RET}$  is the retained Voltage at the Connection Point during a fault,  $T_{CLEAR}$  is the duration of the fault,  $U_{REC}$  and  $t_{REC}$  specify a point of lower limits of Voltage recovery following fault clearance.  $U_{blc}$  is the blocking Voltage at the Connection Point at time  $T_{blc}$ , where  $T_{blc}$  is the instant when the HVDC System deblocks. The time values referred to are measured from  $T_{FAULT}$ .

Voltage parameters [pu]		Time parameters [seconds]	
$U_{RET}$	0.00 – 0.30	$T_{CLEAR}$	0.14-0.25
$U_{REC}$	0.85	$T_{REC}$	1.5 - 10.0
$U_{blc}$	0.0 – 0.75	$T_{blc}$	As defined by Figure 6, and resulting from the other parameter specifications

Table 7: Parameters for Figure 6 for the fault-ride-through capability of a HVDC Converter Station.

- (c) The HVDC Converter Station shall be capable of staying connected to the Network and continue stable operation when the actual course of the phase-to-phase Voltages on the Network Voltage level at the Connection Point during a symmetrical fault, given the pre-fault and post-fault conditions described in Article 30, remain above the lower limit defined in Figure 6, unless the protection scheme for internal faults requires the disconnection of the HVDC Converter Station from the Network. The protection schemes

and settings for internal faults shall be designed not to jeopardize fault-ride-through performance.

- (d) While respecting the provisions of Article 4(3), the Relevant TSO(s) shall have the right to specify Voltages (U<sub>blc</sub>) according to Table 7 at the Connection Point(s) under specific network conditions whereby the HVDC System is allowed to block. Blocking means remaining connected to the Network with no Active and Reactive Power contribution for a time frame that shall be as short as technically feasible and which shall be agreed between the Relevant TSO(s) and the HVDC System Owner, while respecting the provisions of Article 4(3).
- (e) In accordance with the provisions of Article 32, undervoltage protection shall be set by the HVDC System Owner to the widest possible technical capability of the HVDC Converter Station. The Relevant Network Operator may require, while respecting the provisions of Article 4(3), less wide settings according to Article 32.
- (f) Fault-ride-through capabilities in case of asymmetrical faults shall be defined by the Relevant TSO, while respecting the provisions of Article 4(3).

#### **Article 24 Post fault Active Power recovery**

- 1. The Relevant TSO(s) shall specify the magnitude and time of Active Power recovery the HVDC System shall be capable of providing, in accordance with the provisions of Article 23, and while respecting the provisions Article 4(3).

#### **Article 25 Fast recovery of DC faults**

- 1. HVDC Systems including DC overhead lines shall be capable of fast recovery from transient faults within the HVDC System. Details of this capability shall be subject to coordination and agreements on protection schemes and settings according to Article 32.

### **SECTION 4 REQUIREMENTS FOR CONTROL**

#### **Article 26 Converter energisation and synchronisation**

- 1. Unless otherwise instructed by the Relevant Network Operator, the following shall apply:
  - (a) During the energisation or synchronisation of an HVDC Converter Station to the AC Network, the HVDC converter Station shall have the capability to limit any Voltage transients of fundamental Frequency to a level specified by the Relevant Network Operator, but not exceeding 5 per cent of the pre-synchronisation AC Voltage.
  - (b) During the connection of an energised HVDC Converter Station to an HVDC System with more than two converters, the HVDC Converter Unit or HVDC Converter Station shall have the capability to limit any Voltage transients of fundamental Frequency, at any Connection Point of

the HVDC System, to a level specified by the Relevant Network Operator but not exceeding 5 per cent of the pre-synchronisation AC Voltage.

**Article 27 Interaction between HVDC System(s) and/or other plant(s) and equipment**

1. When several HVDC Converter Stations and/or other plant(s) and equipment are within close electrical proximity, the Relevant TSO(s) shall have the right to require and to define, while respecting the provisions of Article 4(3), the scope and extent of studies which demonstrate that no adverse interaction (such as, but not limited to interference with or jeopardisation of the operation of other HVDC Systems, Power Generation Modules or any protection devices in the adjacent AC Network) may occur. If adverse interaction is identified, the studies shall identify possible mitigating actions to be implemented to ensure compliance with the requirements of this Network Code.
2. The studies shall be carried out by the connecting HVDC System Owner with the participation of all other parties identified by the TSO(s) relevant to each new Connection Point. Such other parties shall contribute to the studies and shall provide their input as reasonably required to meet the purposes of the studies. The Relevant TSO shall collect this input and pass it on to the party responsible for the studies in accordance with Article 6.
3. The Relevant TSO shall have the right to replicate the study while respecting the provisions of Article 4(3). The HVDC System Owner shall provide the Relevant TSO all relevant data and models that allow such study to be performed.
4. The Relevant TSO shall assess the result of the studies based on their scope and extent as defined in accordance with Article 27(1). If necessary for the assessment, the Relevant TSO shall have the right to request the HVDC System Owner to perform further studies in line with this same scope and extent.
5. Any necessary mitigating actions identified by the studies and reviewed by the Relevant TSO(s), while respecting the provisions of Article 4(3), shall be undertaken as part of the connection of the new HVDC Converter Station.
6. The Relevant TSO shall have the right, while respecting the provisions of Article 4(3), to specify transient levels of performance associated with events such as switching, load rejection and energisation, for the individual HVDC System or collectively across HVDC Systems commonly impacted to both protect the integrity of TSO equipment and that of Grid Users in a manner consistent with its national code.

**Article 28 Power oscillation damping capability**

1. The HVDC System shall be capable of contributing to the damping of power oscillations in connected AC Networks. The control system of the HVDC System shall not reduce the damping of power oscillations. The Relevant TSO(s) shall specify, while respecting the provisions of Article 4(3), the Network conditions and a Frequency range of oscillations which the control scheme shall positively damp, at least accounting for the dynamic stability assessment studies as prescribed in Article 15 of [NC OS]. The selection of the control parameter settings shall be agreed between the Relevant TSO(s) and the HVDC System Owner.

**Article 29 Sub-synchronous torsional interaction damping capability**



1. With regard to sub-synchronous torsional interaction (SSTI) damping control, the HVDC System shall be capable of contributing to electrical damping of torsional frequencies.
2. The Relevant TSO shall define, while respecting the provisions of Article 4(3), the necessary extent of SSTI studies and provide input parameters, to the extent available, related to the equipment and relevant system conditions in its Network. The SSTI studies shall be provided by the HVDC System Owner. The studies shall identify the conditions, if any, where SSTI exists and propose any necessary mitigation procedure. The necessary contribution to such studies from the owners of other plant(s) and equipment, including but not limited to Existing Power Generating Modules, Existing Distribution Networks, Existing Demand Facilities and Existing HVDC Systems shall not be unreasonably withheld. The Relevant TSO shall collect this input and pass it on to the party responsible for the studies in accordance with Article 6.
3. The Relevant TSO shall have the right to replicate the study while respecting the provisions of Article 4(3). The HVDC System Owner shall provide the Relevant TSO all relevant data and models that allow such study to be performed.
4. The Relevant TSO shall assess the result of the SSTI studies. If necessary for the assessment, the Relevant TSO shall have the right to request the HVDC System Owner to perform further SSTI studies in line with this same scope and extent, while respecting the provisions of Article 4(3).

#### *Article 30* **Network characteristics**

1. With regard to the Network characteristics, the following shall apply for the HVDC Systems:
  - (a) The Relevant Network Operator shall define and make publicly available, while respecting the provisions of Article 4(3), the method and the pre-fault and post-fault conditions for the calculation of at least the minimum and maximum short circuit power at the Connection Point(s).
  - (b) The HVDC System shall be capable of operating within the range of short circuit power and Network characteristics defined by the Relevant Network Operator, while respecting the provisions of Article 4(3).
  - (c) Each Relevant Network Operator shall provide the HVDC System Owner with Network equivalents describing the behaviour of the Network at the Connection Point, enabling the HVDC System Owners to design their system with regard to at least, but not limited to, harmonics and dynamic stability.

#### *Article 31* **HVDC System robustness**

1. The HVDC System shall be capable of finding stable operation points with a minimum change in Active Power flow and Voltage level, during and after any planned or unplanned change in the HVDC System or AC Network to which it is connected. The Relevant TSO(s) shall specify, while respecting the provisions of Article 4(3), the changes in the system conditions for which the HVDC Systems shall remain in stable operation. The changes may include, but are not limited to:
  - (a) loss of communication

- (b) reconfiguring the HVDC or AC system
  - (c) changes in load flow
  - (d) change of control mode
  - (e) control system failure
  - (f) trip of one pole or converter
2. The HVDC System Owner shall ensure that the tripping or disconnection of an HVDC Converter Station, part of any multi-terminal or Embedded HVDC System, does not result in transients at the Connection Point(s) beyond the limit specified by the Relevant TSO(s), while respecting the provisions of Article 4(3).
  3. Transient faults on HVAC lines in the Network adjacent or close to the HVDC System shall not cause any of the equipment in the HVDC System to disconnect from the Network due to auto-reclosure of lines in the Network.
  4. The HVDC System Owner shall provide information to the Relevant Network Operator(s) on the resilience of the HVDC System to AC system disturbances.

## **SECTION 5 REQUIREMENTS FOR PROTECTION DEVICES AND SETTINGS**

### *Article 32* **Electrical protection schemes and settings**

1. The Relevant Network Operator shall define the schemes and settings necessary to protect the Network taking into account the characteristics of the HVDC System. While respecting the provisions of Article 4(3), protection schemes relevant for the HVDC System and the Network and settings relevant for the HVDC System shall be coordinated and agreed between the Relevant Network Operator and the HVDC System Owner. The protection schemes and settings for internal electrical faults shall be designed so as not to jeopardize the performance of the HVDC System in accordance with this Network Code.
2. Electrical protection of the HVDC System shall take precedence over operational controls taking into account system security, health and safety of staff and the public and mitigation of the damage to the HVDC System.
3. While respecting the provisions of Article 4(3), any change to the protection schemes or their settings relevant to the HVDC System and the Network shall be agreed between the Relevant Network Operator and the HVDC System Owner before being implemented by the HVDC System Owner.

### *Article 33* **Priority ranking of protection and control**

1. A control scheme, defined by the HVDC System Owner consisting of different control modes, including the settings of the specific parameters, shall be coordinated and agreed between the Relevant TSO, the Relevant Network Operator and the HVDC System Owner, while respecting the provisions of Article 4(3).
2. With regard to priority ranking of protection and control, the HVDC System Owner shall organise its protections and control devices in compliance with the following priority ranking, listed in decreasing order of importance, unless otherwise specified by the Relevant TSO(s) while respecting the provisions of Article 4(3):

- (a) Network system and HVDC System protection;
- (b) Active Power control for emergency assistance
- (c) Synthetic Inertia, if applicable;
- (d) automatic remedial actions as specified in Article 9(3);
- (e) LFSM;
- (f) FSM and Frequency control ;
- (g) power gradient constraint;

**Article 34 Changes to protection and control schemes and settings**

1. The parameters of the different control modes and the protection settings of the HVDC System shall be able to be changed in the HVDC Converter Station, if required by the Relevant Network Operator in accordance with Article 34(3).
2. Any change to the schemes or settings of parameters of the different control modes and protection of the HVDC System, including the procedure, shall be coordinated and agreed between the Relevant Network Operator and the HVDC System Owner, while respecting the provisions of Article 4(3).
3. The control modes and associated Setpoints of the HVDC System shall be capable of being changed remotely, as defined by the Relevant Network Operator, while respecting the provisions of Article 4(3).

**SECTION 6  
REQUIREMENTS FOR POWER SYSTEM RESTORATION**

**Article 35 Black start**

1. Black Start Capability is not mandatory.
2. If the Relevant TSO(s) deem(s) system security to be at risk due to a lack of Black Start Capability in a Control Area, the Relevant TSO shall have the right to obtain a quote from the HVDC System Owner.
3. An HVDC System with Black Start Capability shall be able to energise the busbar of the remote AC-substation to which it is connected, within a timeframe after shut down determined by the Relevant TSO(s) while respecting the provisions of Article 4(3). The HVDC System shall be able to synchronise within the Frequency limits defined in Article 7 and within the Voltage limits defined by the Relevant TSO or defined by Article 16, where applicable. Wider Frequency and/or Voltage ranges can be defined by the Relevant TSO where needed in order to restore system security.
4. The Relevant TSO(s) and the HVDC System owner shall agree on the capacity and availability of the Black Start Capability and the operational procedure.

## CHAPTER 3

### REQUIREMENTS FOR DC-CONNECTED POWER PARK MODULES AND REMOTE-END HVDC CONVERTER STATIONS

#### SECTION 1

##### REQUIREMENTS FOR DC-CONNECTED POWER PARK MODULES

###### *Article 36* **Scope**

1. The requirements of [NC RfG], as applicable to offshore PPMs with the exception of Articles 24 to 63, shall apply to DC-connected Power Park Modules with the modifications expressed in Article 37 to Article 43 in this Network Code. The categorization in Article 3(6) in [NC RfG] shall apply to DC-connected PPMs.

###### *Article 37* **Frequency stability requirements**

1. With regards to Frequency response:
  - a) A DC-connected Power Park Module shall be capable of receiving a fast signal from a Connection Point in the Synchronous Area to which Frequency response is being provided, within 0.1 second from sending to completion of processing the signal for activation of the response. Frequency shall be measured at the connection point in the Synchronous Area to which Frequency response is being provided.
  - b) DC-connected Power Park Module(s) connected via HVDC system(s) which connect with more than one Control Area shall be capable of delivering coordinated Frequency Control as defined by the Relevant TSO(s), while respecting the provisions of Article 4(3).
2. With regard to Frequency ranges and response:
  - a) A DC-connected Power Park Module shall be capable of staying connected to the Remote-end HVDC Converter Station Network and operating within the Frequency ranges and time periods specified by Table 8 for the 50Hz nominal system. Where a nominal Frequency other than 50Hz, or a Frequency variable by design is used, subject to Relevant TSO(s) agreement and Article 4(3), the applicable Frequency ranges and time periods shall be specified by the Relevant TSO taking into account specificities of the system and the principles laid down in Table 8 and respecting the provisions of Article 4(3).

Frequency range	Time period for operation
47.0 Hz – 47.5 Hz	20 seconds
47.5Hz – 49.0 Hz	90 minutes
49.0 Hz – 51.0 Hz	Unlimited
51.0 Hz – 51.5 Hz	90 minutes
51.5 Hz – 52.0 Hz	15 minutes

Table 8: Minimum time periods for the 50Hz nominal system for which a PPM shall be capable of operating for different Frequencies deviating from a nominal value without disconnecting from the Network.

- b) While respecting the provisions of Article 4(3), wider Frequency ranges or longer minimum times for operation can be agreed between the Relevant TSO and the PPM Owner to ensure the best use of the technical capabilities of a DC-connected Power Park Module if needed to preserve or to restore system security. If wider Frequency ranges or longer minimum times for operation are economically and technically feasible, the consent of the DC-connected Power Park Module Owner shall not be unreasonably withheld.
  - c) While respecting the provisions of Article 37(2)(a), a DC-connected Power Park Module shall be capable of automatic disconnection at specified Frequencies, if required by the Relevant TSO. While respecting the provisions of Article 4(3), terms and settings for automatic disconnection shall be agreed between the Relevant TSO and the DC-connected Power Park Module Owner.
3. With regards to rate-of-change-of-Frequency withstand capability, a DC-connected Power Park Module shall be capable of staying connected to the Remote-end HVDC Converter Station Network and operating at rates of change of Frequency up to +/-2 Hz/s (continuously measured at any point in time as an average of the rate of change of Frequency for the previous 1s) at the Interface Point of the DC-connected Power Park Module at the remote end of the HVDC Converter Station for the 50Hz nominal system.
  4. A capability for Limited Frequency Sensitive Mode - Overfrequency (LFSM-O) of a DC-connected Power Park Module shall be required in accordance with Article 8(1)(c) of the [NC RfG], subject to fast signal response as specified in Article 37(1) of this Network Code for the 50Hz nominal system.
  5. A capability of maintaining constant power for a DC-connected Power Park Module shall be determined in accordance with Article 8(1)(d) of the [NC RfG] for the 50Hz nominal system.
  6. A capability for Active Power controllability of a DC-connected Power Park Module shall be determined in accordance with Article 10(2)(a) of the [NC RfG] for the 50Hz nominal system. Manual control shall be possible in the case that remote automatic control devices are out of service.
  7. A capability for Limited Frequency Sensitive Mode - Underfrequency (LFSM-U) for a DC-connected Power Park Module shall be determined in accordance with Article 10(2)(b) of the [NC RfG], subject to fast signal response as specified in Article 37(1) of this Network Code for the 50Hz nominal system.
  8. A capability for Frequency Sensitive Mode for a DC-connected Power Park Module shall be determined in accordance with Article 10(2)(c) of the [NC RfG], subject to a fast signal

response as specified in Article 37(1) of this Network Code for the 50Hz nominal system. For HVDC connecting PPM the adjustment of Active Power Frequency Response is limited by the capability of the PPM.

9. A capability for Frequency Restoration for a DC-connected Power Park Module shall be determined in accordance with Article 10(2)(d) of the [NC RfG] for the 50Hz nominal system.
10. Where a constant nominal Frequency other than 50 Hz, a Frequency variable by design or a DC system voltage is used, subject to Relevant TSO agreement and Article 4(3), the capabilities listed in Article 37 (3) to (9) above and the parameters associated with such capabilities shall be specified by the Relevant TSO while respecting the provisions of Article 4(3).

**Article 38 Reactive Power and Voltage requirements**

1. With respect to Voltage ranges:
  - a) A DC-connected Power Park Module shall be capable of staying connected to the Remote-end HVDC Converter Station Network and operating within the Voltage ranges (per unit), for the time periods specified by Table 9 or Table 10. The applicable Voltage range and time periods specified are selected based on the nominal Voltage.

Voltage Range	Time period for operation
0.85 pu – 0.90 pu	60 minutes
0.90 pu – 1.10 pu	Unlimited
1.10 pu – 1.12 pu	Unlimited, unless specified otherwise by the Relevant TSO while respecting the provisions of Article 4(3)
1.12 pu – 1.15 pu	To be specified by the Relevant TSO while respecting the provisions of Article 4(3)

Table 9: Minimum time periods for which a PPM shall be capable of operating for different Voltages deviating from a nominal value without disconnecting from the Network for nominal Voltage between 110kV and below 300 kV.

Voltage Range	Time period for operation
0.85 pu – 0.90 pu	60 minutes
0.90 pu – 1.05 pu	Unlimited
1.05 pu – 1.15 pu	To be decided by the Relevant TSO while respecting the provisions of Article 4(3)

Table 10: Minimum time periods for which a PPM shall be capable of operating for different Voltages deviating from a nominal value without disconnecting from the Network for nominal Voltage between 300 kV and 400 kV (included).

- b) While respecting the provisions of Article 4(3), wider Voltage ranges or longer minimum times for operation can be agreed between the Relevant TSO and the DC-connected Power Park Module Owner to ensure the best use of the technical capabilities of a DC-connected Power Park Module if needed to preserve or to

restore system security. If wider Voltage ranges or longer minimum times for operation are economically and technically feasible, the consent of the DC-connected Power Park Module Owner shall not be unreasonably withheld.

- c) For DC Connected PPMs which have an Interface Point to the Remote-end HVDC Converter Network, the Relevant TSO shall have the right to specify Voltages at the Interface Point at which a DC-connected Power Park Module shall be capable of automatic disconnection. The terms and settings for automatic disconnection shall be agreed between the Relevant TSO and the DC-connected Power Park Module Owner, while respecting the provisions of Article 4(3).
  - d) For Interface Point(s) at AC Voltages that are not included in the scope of Table 9 and Table 10, the Relevant TSO(s) shall define applicable requirements at the Connection Point(s), while respecting the provisions of Article 4(3).
  - e) Where frequencies other than nominal 50Hz are used subject to Relevant TSO agreement and Article 4(3), the voltage ranges and time periods specified by the Relevant TSO shall be equitable in proportion to those in Table 9 and 10.
2. With respect to Reactive Power Capability for DC-connected Power Park Modules:
- a) If the DC-connected Power Park Module Owner can obtain a bilateral agreement with the owners of the HVDC System(s) connecting the DC-connected Power Park Module to a single Connection Point on a AC Network, while respecting the provisions of Article 4(3), it has to fulfil all of the following requirements:
    - i. it shall have the ability with additional plant or equipment and/or software, to meet the Reactive Power capabilities prescribed by the Relevant TSO according to Article 38(2)b) and it shall either:
      - have the Reactive Power capabilities prescribed by the Relevant TSO in accordance with Article 38(2)b) already installed as part of the connection of the DC-connected Power Park Module to the AC Network at the time of initial connection and commissioning; or
      - demonstrate to, and then reach agreement with, the Relevant TSO on how the Reactive Power capability will be provided when the DC-connected Power Park Module is connected to more than a single Connection Point in the AC Network, or the Remote-end HVDC Converter Network has either another DC-connected Power Park Module or HVDC System with a different owner connected to it. This agreement will include a contract by the DC-connected Power Park Module Owner (or any subsequent owner), that it will finance and install Reactive Power capabilities required by this Article for its PPMs at a point in time defined by the Relevant TSO. The Relevant TSO shall inform the DC Connected Power Park Module Owner of the proposed completion date of any committed development which will require the DC Connected PPM to install the full Reactive Power capability.
    - ii. The Relevant TSO, while respecting the provisions of Article 4(3), must account for the development time schedule of retrofitting the Reactive Power capability to the DC-connected Power Park Module in specifying the point in time by which this Reactive Power capability retrofitting is to take place. The development time

schedule shall be provided by the DC-connected Power Park Module Owner at the time of connection to the AC Network.

b) DC-connected Power Park Modules shall fulfil the following requirements referring to Voltage stability either at the time of connection or subsequently to the agreement as referred to in Article 38(2)a):

i. With regard to Reactive Power capability at Maximum HVDC Active Power Transmission Capacity, the Relevant TSO shall define while respecting the provisions of Article 4(3) the Reactive Power provision capability requirements in the context of varying Voltage. For doing so, it shall define a U-Q/P<sub>max</sub>-profile that may take any shape with ranges in accordance with Table 11, of which the Power Park Module shall be capable of providing Reactive Power at its Maximum HVDC Active Power Transmission Capacity. The Relevant TSO shall consider the long term development of the Network when determining these ranges.




Figure 7: U-Q/P<sub>max</sub>-profile of a DC-connected Power Park Module at the Connection Point. The diagram represents boundaries of a U-Q/P<sub>max</sub>-profile of the Voltage at the Connection Point[s], expressed by the ratio of its actual value to its nominal value in per unit, against the ratio of the Reactive Power (Q) to the Maximum Capacity (P<sub>max</sub>). The position, size and shape of the inner envelope are indicative and other than rectangular may be used within the Inner Envelope. For profile shapes other than rectangular, the Voltage range represents the highest and lowest Voltage points. Such a profile would not give rise to the full Reactive Power range being available across the range of steady-state Voltages;



Range of width of Q/Pmax profile	Range of steady-state Voltage level in pu
0 - 0.95	0.1 - 0.225

Table 11: maximum and minimum range of both Q/Pmax and steady-state Voltage level range for a DC-connected PPM

If the Relevant TSO motivates in the relevant long-term development plan of the Network that the DC-connected PPM becomes AC connected to the Synchronous Area, either:

- the PPM shall have the capabilities prescribed in Article 20(3) of the [NC RfG] for that Synchronous Area installed at the time of initial connection and commissioning of the DC-connected Power Park Module to the AC Network; or
  - the PPM Owner shall demonstrate to, and then reach agreement with, the Relevant TSO on how the Reactive Power capability prescribed in Article 20(3) of the [NC RfG] for that Synchronous Area will be provided in the event that the DC-connected PPM becomes AC connected to the Synchronous Area .
- ii. With regard to Reactive Power Capability, for Power Park Modules where
- the Connection Point is not at the location of the high-voltage terminals of its step-up transformer, or
  - where no step up transformer exists at the terminals of the high-voltage line or cable to the Connection Point at the Power Park Module,

Supplementary Reactive Power may be required by the Relevant TSO while respecting the provisions of Article 4(3) to compensate for the Reactive Power consumption of the high-voltage line or cable between these two points from the responsible owner of this line or cable.

3. With regard to priority to Active or Reactive Power contribution for DC-connected Power Park Modules, the Relevant TSO shall define, while respecting the provisions of Article 4(3), whether Active Power contribution or Reactive Power contribution has priority during faults for which fault-ride-through capability is required. If priority is given to Active Power contribution, its provision shall be established within a time from the fault inception as defined by Relevant TSO while respecting the provisions of Article 4(3).

#### Article 39 Control Requirements

1. During the energisation or synchronisation of a Power Park Module to the AC collection Network at the Connection Point(s), the Power Park Module shall limit any Voltage transients at fundamental frequency to a steady-state level as specified by the Relevant Network Operator but not exceeding 5 per cent of the pre-synchronisation AC Voltage.
2. With regard to Active Power controllability and control range, the PPM control system shall be capable of adjusting an Active Power Setpoint as instructed by the Relevant TSO within a period specified and within a defined tolerance (subject to the availability of the prime

mover resource), subject to notification to the National Regulatory Authority. The modalities of that notification shall be determined in accordance with the applicable national regulatory framework. The Relevant TSO shall provide the PPM owner with the defined minimum periods and tolerance.

3. The DC-connected PPM Owner shall provide output signals as specified by the Relevant TSO, while respecting the provisions of Article 4(3).

#### *Article 40* **Network characteristics**

1. With regard to the Network characteristics, the following shall apply for the DC-connected Power Park Modules:
  - (a) Each Relevant TSO shall define and make publicly available, while respecting the provisions of Article 4(3), the method and the pre-fault and post-fault conditions for the calculation of minimum and maximum short circuit power at the Connection Point.
  - (b) The DC-connected Power Park Module shall be capable of stable operation within the minimum to maximum short circuit range of short circuit power and Network characteristics of the Connection Point defined by the Relevant TSO.
  - (c) Each Relevant TSO and HVDC System Owner shall provide the DC-connected Power Park Module Owner with equivalents representing the system, enabling the DC-connected Power Park Module Owners to design their system with regard to harmonics.

#### *Article 41* **Protection requirements**

1. Electrical protection schemes and settings of Power Park Modules shall be determined in accordance with Article 9(5)b of the [NC RfG], where the Network refers to the Synchronous Area Network. The protection schemes have to be designed taking into account the system performance, grid specificities as well as technical specificities of the Power Park Module technology and agreed with the Relevant TSO(s).
2. Priority ranking of protection and control of Power Park Modules shall be determined in accordance with Article 9(5)c of the [NC RfG], where the Network refers to the Synchronous Area Network, and agreed with the Relevant TSO(s).

#### *Article 42* **Power Quality**

1. DC-connected Power Park Modules Owners shall ensure that their connection to the Network does not result in a level of distortion or fluctuation of the supply Voltage on the Network, at the Connection Point, exceeding the level allocated to them by the Relevant TSO, while respecting the provisions of Article 4(3). The necessary contribution to such studies from the Grid Users, including but not limited to Existing DC-connected Power Park Modules and Existing HVDC Systems shall not be unreasonably withheld. The process for necessary studies to be conducted and relevant data to be provided by all Grid Users involved, as well as mitigating actions identified and implemented shall be in accordance with the process in Article 27.

*Article 43* **General System Management Requirements applicable to DC connected PPMs**

1. With regard to general system management requirements, Articles 9(5), 10(6) and 11(4) of the [NC RfG] shall apply to any DC-connected Power Park Module.

**SECTION 2  
REQUIREMENTS FOR REMOTE-END HVDC CONVERTER STATIONS**

*Article 44* **Scope**

1. The requirements of Article 7 to Article 35 apply to Remote-end HVDC Converter Stations, with the modifications expressed in Article 45 to Article 49.

*Article 45* **Frequency stability requirements**

1. Where a nominal Frequency other than 50Hz, or a Frequency variable by design is used in the Network connecting the DC-connected PPM(s), subject to Relevant TSO(s) agreement and Article 4(3), Article 7 shall apply to the Remote-end HVDC Converter Station with the applicable Frequency ranges and time periods specified by the Relevant TSO, taking into account specificities of the system and the principles laid down in Table 1, and respecting the provisions of Article 4(3).
2. With regards to Frequency response, the Remote-end HVDC Converter Station Owner and the DC-connected Power Park Module Owner shall agree on the technical modalities of the fast signal communication in accordance with Article 37(1), while respecting the provisions of Article 4(3). Where the Relevant TSO requires, the HVDC System shall be capable of providing the Network Frequency at the Connection Point as a signal.

*Article 46* **Reactive Power and Voltage requirements**

1. With respect to Voltage ranges:
  - a) A Remote-end HVDC Converter shall be capable of staying connected to the Remote-end HVDC Converter Station Network and operating within the Voltage ranges (per unit) and time periods specified by Table 12 or Table 13. The applicable Voltage range and time periods specified are selected based on the nominal Voltage.

Voltage Range	Time period for operation
0.85 pu – 0.90 pu	60 minutes
0.90 pu – 1.10 pu	Unlimited
1.10 pu – 1.12 pu	Unlimited, unless specified otherwise by the Relevant TSO while respecting the provisions of Article 4(3)
1.12 pu – 1.15 pu	To be decided by the Relevant TSO while respecting the provisions of Article 4(3)

Table 12: Minimum time periods for which a Remote-end HVDC Converter shall be capable of operating for different Voltages deviating from a nominal value without disconnecting from the Network (for nominal Voltage between 110kV and below 300 kV).

Voltage Range	Time period for operation
0.85 pu – 0.90 pu	60 minutes
0.90 pu – 1.05 pu	Unlimited
1.05 pu – 1.15 pu	To be decided by the Relevant TSO while respecting the provisions of Article 4(3)

Table 13: Minimum time periods for which a Remote-end HVDC Converter shall be capable of operating for different Voltages deviating from a nominal value without disconnecting from the Network (for nominal Voltage between 300 kV and 400 kV, included).

- b) While respecting the provisions of Article 4(3), wider Voltage ranges or longer minimum times for operation can be agreed between the Relevant TSO and the DC-connected Power Park Module Owner in accordance with Article 38.
  - c) For Interface Point(s) at AC Voltages that are not included in the scope of Table 912 and Table 103, the Relevant TSO(s) shall define applicable requirements at the Connection Point(s), while respecting the provisions of Article 4(3).
  - d) Where frequencies other than nominal 50Hz are used subject to Relevant TSO agreement and Article 4(3), the voltage ranges and time periods specified by the Relevant TSO shall be equitable in proportion to those in Table 12 and 13.
2. A Remote-end HVDC Converter Station shall fulfil the following requirements referring to Voltage stability, at the Connection Point(s) with regard to Reactive Power capability:
- a) The Relevant TSO shall define, while respecting the provisions of Article 4(3), the Reactive Power provision capability requirements for various Voltage levels. In doing so, the Relevant TSO(s) shall define a U-Q/Pmax-profile of any shape and within the boundaries of which the Remote-end HVDC Converter Station shall be capable of providing Reactive Power at its Maximum HVDC Active Power Transmission Capacity.
    - iii. The U-Q/Pmax-profile shall be defined by each Relevant TSO while respecting the provisions of Article 4(3). The U-Q/Pmax-profile shall be within the range of Q/Pmax and steady state Voltage in Table 14 With regard to Reactive Power Capability, for Power Park Modules where

- the Connection Point is not at the location of the high-voltage terminals of its step-up transformer, or
- where no step up transformer exists at the terminals of the high-voltage line or cable to the Connection Point at the Power Park Module,

Supplementary Reactive Power may be required by the Relevant TSO while respecting the provisions of Article 4(3) to compensate for the Reactive Power consumption of the high-voltage line or cable between these two points from the responsible owner of this line or cable.

- b) , and the position of the U-Q/Pmax-profile envelope shall lie within the limits of the fixed outer envelope in Figure 5 in Article 18. The Relevant TSO shall consider the long term development of the Network when determining these ranges.

Maximum range of Q/Pmax	Maximum range of steady-state Voltage level in PU
0.95	0.225

Table 14: Maximum range of both Q/Pmax and steady-state Voltage range for a Remote-end HVDC Converter Station

When the Relevant TSO motivates in the relevant long-term development plan of the Network that the Remote-end HVDC Converter Station is reasonably expected to become AC connected to the Synchronous Area, the HVDC Converter Station must have the ability to provide the Reactive Power according to Article 20(3) of the [NC RfG] and either:

- have the capabilities of Article 20(3) of the [NC RfG] for that Synchronous Area already installed as part of the connection of the DC-connected Power Park Module to the AC Network at the time of initial connection and commissioning; or
- demonstrate to, and then reach agreement with the Relevant TSO, while respecting the provisions of Article 4(3), on how the Reactive Power capability will be provided in the event that the DC-connected PPM becomes AC connected to the Synchronous Area.

#### Article 47 Control Requirements

1. During the energisation or synchronisation of a Remote-end HVDC Converter Station to the AC collection Network at the Connection Point(s), the Remote-end HVDC Converter Station shall limit any Voltage transients at fundamental frequency to a steady-state level as specified by the Relevant Network Operator but not exceeding 5 per cent of the pre-synchronisation AC Voltage.
2. During the synchronisation of an energised Remote-end HVDC Converter Station to an HVDC System, the Remote-end HVDC Converter Station shall limit any Voltage transients at fundamental frequency, at any Connection Point of the HVDC System, to a steady-state level

as specified by the Relevant Network Operator but not exceeding 5 per cent of the pre-synchronisation AC Voltage

*Article 48* **Network characteristics**

1. With regard to the Network characteristics, the Remote-end HVDC Converter Station owner shall provide relevant data to any DC-collected PPM Owner in accordance with Article 40.

*Article 49* **Power Quality**

1. Remote-end HVDC Converter Station Owners shall ensure that their connection to the Network does not result in a level of distortion or fluctuation of the supply Voltage on the Network, at the Connection Point, exceeding the level allocated to them by the Relevant TSO, while respecting the provisions of Article 4(3). The necessary contribution to such studies from the Grid Users, including but not limited to Existing DC-connected Power Park Modules and Existing HVDC Systems shall not be unreasonably withheld. The process for necessary studies to be conducted and relevant data to be provided by all Grid Users involved, as well as mitigating actions identified and implemented shall be in accordance with the process in Article 27.

## CHAPTER 4 INFORMATION EXCHANGE AND COORDINATION

### Article 50 Operation

1. With regard to instrumentation for the operation, each HVDC Converter Unit of the HVDC System shall be equipped with an automatic controller capable of receiving Instructions from the Relevant Network Operator(s). This automatic controller shall be capable of operating the HVDC Converter Units of the HVDC System in a coordinated way. The Relevant Network Operator(s) shall define, while respecting the provisions of Article 4(3), the automatic controller hierarchy per HVDC Converter Unit.
  - a) The signal types exchanged from the automatic controller of the HVDC System to the Relevant Network Operator(s) are:
    - operational signals;
    - alarm signals;
    - i. With regard to operational signals per HVDC Converter Unit, those are classified, but not limited to, by the following, as applicable:
      - Startup;
      - AC and DC voltage measurements;
      - AC and DC current measurements;
      - Active and Reactive Power measurements on the AC side;
      - Active DC power measurements;
      - Multi-pole operational type at HVDC Converter Units level with regard to HVDC System;
      - Elements and topology status;
      - FSM, LFSM-O and LFSM-U active power ranges;
    - ii. With regard to alarm signals per HVDC Converter Unit, those are classified, but not limited to, by the following, as applicable:
      - Emergency blocking;
      - Ramp blocking;
      - Active Power reversal;
      - Fast Active Power reversal
  - b) The signal types exchanged from the Relevant Network Operator(s) to the automatic controller of the HVDC system are:
    - operational signals;
    - alarm signals;
    - i. With regard to operational signals per HVDC Converter Unit, those are classified, but not limited to, by the following, as applicable:
      - Start-up command;
      - Active Power Setpoints;
      - Frequency Sensitive Mode settings;
      - Reactive Power, Voltage or similar Setpoints;
      - Reactive Power control modes;
      - Power oscillation damping control;
      - Synthetic Inertia;

- With regard to urgent alarm signals per HVDC Converter Unit, those are classified, but not limited to, by the following, as applicable: Emergency blocking command;
  - Ramp blocking command;
  - Active Power flow direction;
  - Fast Active Power reversal command
- c) With regards to each signal, the Relevant Network Operator shall have the right to define, while respecting the provisions of Article 4(3), the quality of the supplied signal.

*Article 51*  
**Parameter setting**

While respecting the provisions of Article 4(3), the parameters and settings of the main control functions of the HVDC System shall be agreed between the HVDC System Owner and the Relevant Network Operator in coordination with the Relevant TSO(s). The parameters and settings shall be implemented within such a control hierarchy that makes their modification possible if necessary. These main control functions are at least:

- Synthetic Inertia, if applicable as defined in Article 10 and Article 37;
- Frequency Sensitive Modes (FSM, LFSM-O, LFSM-U) defined in Articles 11, 12 and 13;
- Frequency Control, if applicable, defined in Article 14;
- Reactive Power control mode, if applicable as defined in Article 20;
- Power oscillation damping capability, defined in Article 28;
- Sub-synchronous torsional interaction damping capability, defined in Article 29.

*Article 52*  
**Fault recording and Monitoring**

1. With regard to instrumentation:

- a) A HVDC System shall be equipped with a facility to provide fault recording and dynamic system behaviour monitoring of the following parameters for each of its HVDC Converter Stations:
- AC and DC voltage;
  - AC and DC current;
  - Active Power;
  - Reactive Power; and
  - Frequency.

The Relevant Network Operator shall have the right to define, while respecting the provisions of Article 4(3), quality of supply parameters to be complied with provided a reasonable prior notice is given.

- b) While respecting the provisions of Article 4(3), the particulars of the fault recording equipment, including analogue and digital channels, the settings, including triggering criteria and the sampling rates shall be agreed between the HVDC System Owner and the Relevant Network Operator.



- c) All dynamic system behaviour monitoring shall include an oscillation trigger, specified by the Relevant Network Operator, while respecting the provisions of Article 4(3), for detecting poorly damped power oscillations.
- d) The facilities for quality of supply and dynamic system behaviour monitoring shall include arrangements for the HVDC System Owner and/or the Relevant Network Operator to access the information electronically. While respecting the provisions of Article 4(3), the communications protocols for recorded data shall be agreed between the HVDC System Owner and the Relevant Network Operator.

*Article 53*  
**Simulation models**

1. While respecting the provisions of Article 4(3), the Relevant Network Operator in coordination with the Relevant TSO shall have the right to require the HVDC System Owner to deliver simulation models which properly reflect the behaviour of the HVDC System in both steady-state, dynamic simulations (fundamental frequency component) and in electromagnetic transient simulations.  
The format in which models shall be provided and the provision of documentation of models structure and block diagrams shall be defined by the Relevant Network Operator in coordination with the Relevant TSO.
2. For the purpose of dynamic simulations, the models provided shall contain the following sub-models, depending on the existence of the mentioned components:
  - HVDC Converter Unit models
  - AC component models
  - DC grid models
  - Voltage and power control
  - Special control features if applicable e.g. Power Oscillation Damping (POD) function, Sub Synchronous Torsional Interaction (SSTI) control
  - Multi terminal control, if applicable
  - HVDC System protection models as agreed between the Relevant TSO and the Power Generating Facility Owner, while respecting the provisions of Article 4(3)
3. The models shall be verified against the results of compliance tests carried out according to CHAPTER 6. They shall then be used for the purpose of verifying the requirements of this Network Code including but not limited to Compliance Simulations as defined in CHAPTER 6 and for use in studies for continuous evaluation in system planning and operation.
4. The Relevant Network Operator and the Relevant TSO shall have the right to require, while respecting the provisions of Article 4(3), HVDC System recordings in order to compare the response of the models with these recordings.
5. The Relevant Network Operator(s) and the Relevant TSO(s) shall have the right, while respecting the provisions of Article 4(3), to require the HVDC System Owner to deliver a replica of the exact control system when adverse control interactions may result with HVDC Converter Stations and other connections in close electrical proximity.

## CHAPTER 5 OPERATIONAL NOTIFICATION PROCEDURE FOR CONNECTION

### SECTION 1 OPERATIONAL NOTIFICATION PROCEDURE FOR CONNECTION OF NEW HVDC SYSTEMS

#### *Article 54*

##### **General provisions**

1. The provisions of CHAPTER 5, Section 1 shall apply to New HVDC Systems only.
2. The HVDC System Owner shall demonstrate to the Relevant Network Operator(s) its compliance with the requirements referred to in CHAPTER 2 to CHAPTER 4 of this Network Code at the respective Connection Point by completing successfully the operational notification procedure for connection of the HVDC System as defined in Article 55 through to Article 58.
3. Further details of the operational notification procedure shall be defined and made publicly available by the Relevant Network Operator(s) while respecting the provisions of Article 4(3).
4. The operational notification procedure for connection for each New HVDC System shall comprise:
  - a) Energisation Operational Notification (EON);
  - b) Interim Operational Notification (ION);and
  - c) Final Operational Notification (FON).

#### *Article 55* **Energisation Operational Notification (EON) for HVDC Systems**

1. An Energisation Operational Notification (EON) shall entitle the HVDC System Owner to energise its internal Network and auxiliaries and connect it to the Network at its defined Connection Point(s).
2. An Energisation Operational Notification (EON) shall be issued by the Relevant Network Operator(s), subject to completion of preparation and the fulfilment of the requirements defined by the Relevant Network Operator(s), while respecting the provisions of Article 4(3), in the relevant operational procedures. This preparation will include agreement on the protection control relevant to the Connection Point(s) between the Relevant Network Operator(s) and the HVDC System Owner.

#### *Article 56* **Interim Operational Notification (ION) for HVDC Systems**

1. Interim Operational Notification (ION) shall entitle the HVDC System Owner or HVDC Converter Unit Owner to operate the HVDC System or HVDC Converter by using the Network connection(s) that is defined by the Connection Point(s) for a limited period of time.
2. An Interim Operational Notification shall be issued by the Relevant Network Operator(s) on the completion of data and study review process, while respecting the provisions of Article 4(3), if applicable.

3. For the purpose of the completion of data and study review, the Relevant Network Operator(s) shall have the right to request the following from the HVDC System or HVDC Converter Unit:
  - itemized Statement of Compliance;
  - detailed technical data of the HVDC System with relevance to the Network connection, that is defined by the Connection Point(s), as specified by the Relevant Network Operator(s) in coordination with the Relevant TSO(s), while respecting the provisions of Article 4(3);
  - Equipment Certificates of HVDC Systems or HVDC Converter Units where these are relied upon as part of the evidence of compliance;
  - simulation models or a replica of the exact control system as specified by Article 53 and as required by the Relevant Network Operator(s) in coordination with the Relevant TSO(s) while respecting the provisions of Article 4(3);
  - studies demonstrating expected steady-state and dynamic performance as required by CHAPTER 2, CHAPTER 3 and CHAPTER 4 of this Network Code;
  - details of intended Compliance Tests according to Article 68.
  - details of intended practical method of completing Compliance Tests according to Chapter 6.
4. The maximum period for the HVDC System Owner or HVDC Converter Unit Owner to remain in the Interim Operational Notification status shall not exceed twenty four months. The Relevant Network Operator(s) shall be entitled to specify a shorter Interim Operational Notification validity period in accordance with Article 4(2). The ION validity period shall be subject to notification to the National Regulatory Authority. The modalities of that notification shall be determined in accordance with the applicable national regulatory framework. ION extension shall be granted only if the HVDC System Owner demonstrates substantial progress towards full compliance. At the time of Interim Operational Notification extension, the outstanding issues shall be explicitly identified.
5. A prolongation of the twenty four month period for the HVDC System to remain in the Interim Operational Notification status may be granted upon request for Derogation made to the Relevant Network Operator(s). The request shall be made before the expiry of the twenty four month period and in accordance with the Derogation procedure defined in this Network Code.

#### *Article 57* **Final Operational Notification (FON) for HVDC Systems**

1. A Final Operational Notification (FON) shall entitle the HVDC System Owner to operate the HVDC System or HVDC Converter Unit(s) by using the grid Connection Point(s).
2. A Final Operational Notification (FON) shall be issued by the Relevant Network Operator(s), upon prior removal of all incompatibilities identified for the purpose of the Interim Operational Notification (ION) status and subject to the completion of data and study review process as required by this Network Code.
3. For the purpose of the completion of data and study review, the Relevant Network Operator(s) in coordination with the Relevant TSO(s) shall have the right to request the following from the HVDC System Owner:
  - Itemized Statement of Compliance; and
  - Update of applicable technical data, simulation models, a replica of the exact control system and studies as referred to in Article 56, including use of actual measured values during testing.

4. In case of incompatibility identified for the purpose of the granting of the Final Operational Notification (FON), derogation may be granted upon request made to the Relevant Network Operator, in accordance with the derogation procedure according to CHAPTER 7. A Final Operational Notification (FON) shall be issued by the Relevant Network Operator(s), if the HVDC System is compliant with the provisions of the derogation. The Relevant Network Operator(s) shall have the right to refuse the operation of the HVDC System or HVDC Converter Unit(s), whose owner's request for derogation was rejected, until the HVDC System Owner and the Relevant Network Operator(s) have established a resolution of the incompatibility and the HVDC System is considered to be compliant by the Relevant Network Operator(s).

*Article 58* **Limited Operational Notification (LON) for HVDC Systems**

1. HVDC System Owners to whom a Final Operational Notification (FON) has been granted shall inform the Relevant Network Operator(s) immediately in the following circumstances:
  - the HVDC System is temporarily subject to either a significant modification or loss of capability, due to implementation of one or more modifications of significance to its performance; or
  - in case of equipment failures leading to non-compliance with some relevant requirements.
2. The HVDC System Owner shall apply to the Relevant Network Operator(s) for a Limited Operational Notification (LON), if the HVDC System Owner reasonably expects the circumstances according to Article 58(1) to persist for more than three months.
3. A Limited Operational Notification (LON) shall be issued by the Relevant Network Operator(s) with a clear identification of:
  - the unresolved issues justifying the granting of the Limited Operational Notification (LON);
  - the responsibilities and timescales for expected solution; and
  - a maximum period of validity which shall not exceed twelve months. The initial period granted may be shorter, with possibility for extension, if evidence to the satisfaction of the Relevant Network Operator(s) has been made, which demonstrates that substantial progress has been made in terms of achieving full compliance.
4. The Final Operational Notification (FON) shall be suspended during the period of validity of the Limited Operational Notification (LON) with regard to the subjects for which the Limited Operational Notification (LON) has been issued.
5. A further prolongation of the period of validity of the Limited Operational Notification (LON) may be granted upon request for derogation made to the Relevant Network Operator(s), before the expiry of that period, in accordance with the derogation procedure according to Article 74.
6. The Relevant Network Operator(s) shall have the right to refuse the operation of the HVDC System, if the Limited Operational Notification (LON) terminates without removal of the circumstances which caused its issuing. In such a case the Final Operational Notification (FON) shall automatically be invalid.

## **SECTION 2 OPERATIONAL NOTIFICATION PROCEDURE FOR CONNECTION OF NEW DC-CONNECTED POWER PARK MODULES**

### *Article 59* **General provisions**

1. The provisions of CHAPTER 5, Section 2 shall apply to New DC-connected Power Park Modules only.
2. The DC-connected Power Park Module Owner shall demonstrate to the Relevant Network Operator(s) its compliance with the requirements referred to in CHAPTER 3 of this Network Code at the respective Connection Point by completing successfully the operational notification procedure for connection of the DC-connected Power Park Module as defined in Article 60 through Article 63.
3. Further details of the operational notification procedure shall be defined and made publicly available by the Relevant Network Operator(s) while respecting the provisions of Article 4(3).
4. The operational notification procedure for connection for each New DC-connected Power Park Module shall comprise:
  - a) Energisation Operational Notification (EON);
  - b) Interim Operational Notification (ION);and
  - c) Final Operational Notification (FON).

### *Article 60* **Energisation Operational Notification (EON) for DC-connected Power Park Modules**

1. An Energisation Operational Notification (EON) shall entitle the Owner of a DC-connected Power Park Module to energise its internal Network and auxiliaries by using the grid connection that is defined by the Connection Point.
2. An Energisation Operational Notification (EON) shall be issued by the Relevant Network Operator(s), subject to completion of preparation including agreement on the protection and control settings relevant to the Connection Point between the Relevant Network Operator(s) and the DC-connected Power Park Module.

### *Article 61* **Interim Operational Notification (ION) for DC-connected Power Park Modules**

1. An Interim Operational Notification (ION) shall entitle the DC-connected Power Park Module Owner to operate the DC-connected Power Park Module and generate power by using the grid connection for a limited period of time.
2. An Interim Operational Notification (ION) shall be issued by the Relevant Network Operator(s), subject to the completion of data and study review process as required by this Network Code, if applicable.
3. With respect to data and study review the Relevant Network Operator(s) shall have the right to request the following from the Power Generating Facility Owner:
  - itemized Statement of Compliance;
  - detailed technical data of the Power Park Module with relevance to the grid connection, that is defined by the Connection Point(s) as specified by the Relevant Network Operator(s) in coordination with the Relevant TSO(s), while respecting the provisions of Article 4(3);

- Equipment Certificates of Power Park Module, where these are relied upon as part of the evidence of compliance;
  - simulation models as specified by Article 43 and as required by the Relevant Network Operator(s) in coordination with the Relevant TSO while respecting the provisions of Article 4(3);
  - studies demonstrating expected steady-state and dynamic performance as required by CHAPTER 3 of this Network Code; and
  - details of intended compliance tests according to Article 69.
4. The maximum period for the DC-connected Power Park Module Owner to remain in the Interim Operational Notification (ION) status shall not exceed twenty-four months. The Relevant Network Operator(s) shall be entitled to specify a shorter ION validity period in accordance with Article 4(2). The ION validity period shall be subject to notification to the National Regulatory Authority. The modalities of that notification shall be determined in accordance with the applicable national regulatory framework. ION extensions shall be granted only if the DC-connected Power Park Module Owner demonstrates substantial progress towards full compliance. At the time of ION extension, the outstanding issues should be explicitly identified.
5. A prolongation of the maximum period for the DC-connected Power Park Module Owner to remain in the Interim Operational Notification (ION) status (beyond a total of twenty-four months) may be granted upon request for derogation made to the Relevant Network Operator(s) before the expiry of that period in accordance with the derogation procedure defined in the Code.

#### *Article 62*

#### **Final Operational Notification (FON) for DC-connected Power Park Modules**

1. A Final Operational Notification (FON) shall entitle the DC-connected Power Park Module Owner to operate the DC-connected Power Park Module by using the grid connection that is defined by the Connection Point.
2. A Final Operational Notification (FON) shall be issued by the Relevant Network Operator(s), upon prior removal of all incompatibilities identified for the purpose of the Interim Operational Notification (ION) status and subject to the completion of data and study review process as required by this Network Code.
3. For the purpose of the completion of data and study review, the Relevant Network Operator(s) shall have the right to request the following from the DC-connected Power Park Module Owner:
  - Itemized Statement of Compliance; and
  - Update of applicable technical data, simulation models and studies as referred to in Article 61(3), including use of actual measured values during testing.
4. In case of incompatibility identified for the purpose of the granting of the Final Operational Notification (FON), derogation may be granted upon request made to the Relevant Network Operator(s), in accordance with the derogation procedure according to CHAPTER 7. A Final Operational Notification (FON) shall be issued by the Relevant Network Operator(s), if the DC-connected Power Park Module is compliant with the provisions of the derogation. The Relevant Network Operator(s) shall have the right to refuse the operation of the DC-connected Power Park Module, whose owner's request for derogation was rejected, until the DC-connected Power Park Module Owner and the Relevant Network Operator(s) have established a resolution of the

incompatibility and the DC-connected Power Park Module is considered to be compliant by the Relevant Network Operator(s).

*Article 63* **Limited Operational Notification (LON) for DC-connected Power Park Modules**

1. DC-connected Power Park Module Owners to whom a Final Operational Notification (FON) has been granted shall inform the Relevant Network Operator immediately in the following circumstances:
  - the DC-connected Power Park Module is temporarily subject to either a significant modification or loss of capability, due to implementation of one or more modifications of significance to its performance; or
  - in case of equipment failures leading to non-compliance with some relevant requirements.
2. The DC-connected Power Park Module Owner shall apply to the Relevant TSO for a Limited Operational Notification (LON), if the DC-connected Power Park Module Owner reasonably expects the circumstances according to Article 63(1) to persist for more than three months.
3. A Limited Operational Notification (LON) shall be issued by the Relevant TSO with a clear identification of:
  - the unresolved issues justifying the granting of the Limited Operational Notification (LON);
  - the responsibilities and timescales for expected solution; and
  - a maximum period of validity which shall not exceed twelve months. The initial period granted may be shorter, with possibility for extension, if evidence to the satisfaction of the Relevant Network Operator has been made, which demonstrates that substantial progress has been made in terms of achieving full compliance.
4. The Final Operational Notification (FON) shall be suspended during the period of validity of the Limited Operational Notification (LON) with regard to the subjects for which the Limited Operational Notification (LON) has been issued.
5. A further prolongation of the period of validity of the Limited Operational Notification (LON) may be granted upon request for derogation made to the Relevant Network Operator, before the expiry of that period, in accordance with the derogation procedure according to CHAPTER 7.
6. The Relevant Network Operator shall have the right to refuse the operation of the DC-connected Power Park Module, if the Limited Operational Notification (LON) terminates without removal of the circumstances which caused its issuing. In such a case the Final Operational Notification (FON) shall automatically be invalid.

**SECTION 3 OPERATIONAL NOTIFICATION PROCEDURE FOR EXISTING HVDC SYSTEMS**

*Article 64*  
**General provisions**

1. In order to assess the advantages of the applicability of any requirement set forth in this Network Code to Existing HVDC Systems, the Relevant TSO shall initiate a preparatory process aimed at identifying cases of merit with the phases defined in Article 64(2) to (8) below. This preparatory

process shall consist of a qualitative comparison of costs and benefits related to the requirement under consideration for application to Existing HVDC Systems taking into account Network-based or market-based alternatives, where applicable. If the Relevant TSO deems the cost of applying the requirement to be low and the benefit to be high then the case can proceed as defined below. If however, the cost is deemed high and or the benefit is deemed low then the Relevant TSO may not proceed further.

2. The TSO shall carry out a quantitative Cost-Benefit Analysis of a requirement under consideration for application to Existing HVDC Systems that has demonstrated potential benefits as a result of the preparatory process according to Article 64(1) above. This Cost-Benefit Analysis shall be followed by a public consultation. The public consultation shall include, amongst others, a proposal for a transition period for applying a requirement to Existing HVDC Systems. Such a transition period should not exceed two years from the decision of the National Regulatory Authority on the applicability.
3. Existing HVDC System Owners and Distribution Network Operators shall assist and contribute to this Cost-Benefit Analysis and provide the relevant data as requested by the Relevant TSO within three months after reception of the request, unless agreed otherwise.
4. The Cost-Benefit Analysis shall be undertaken using one or more of the following calculating principles:
  - net present value;
  - return on investment;
  - rate of return; and
  - time to break-even.

The quantified benefits shall include any marginal socio-economic benefits in terms of improvement of security of supply including, but not limited to:

- associated reduction in probability of loss of supply over the lifetime of the modification;
- the probable extent and duration of such loss of supply;
- the societal cost per hour of such loss of supply;

as well as benefits to the internal market in electricity, cross-border trade and integration of renewable energies including, but not limited to:

- Frequency response;
- reserve holding;
- Reactive Power provision;
- congestion management; and
- defence measures.

The quantified costs shall include as appropriate, but are not limited to:

- costs for implementing the requirement;
- any attributable loss of opportunity; and/or
- change in maintenance and operating costs.

5. If the socio-economic benefits outweigh the costs of applying the requirement under consideration to Existing HVDC Systems, the Relevant TSO shall summarise the analysis within three months in a report which shall include a recommendation on how to proceed. This report shall be subject to public consultation. If, taking due account of the outcome of the public consultation, the Relevant TSO decides to proceed with the issue, the report including such



consultation outcome and a proposal on the applicability of the requirement under consideration to Existing HVDC Systems, shall be forwarded to the Relevant National Regulatory Authority within six months for decision.

6. The proposal by the Relevant TSO to the National Regulatory Authority according to Article 64(5) on applicability of any requirement of this Network Code to Existing HVDC Systems shall include the following:
  - a) an operational notification procedure in order to demonstrate the implementation of the requirements by the Existing HVDC System Owner;
  - b) an appropriate transition period for implementing the requirements. The determination of the transition period shall take into account the category of HVDC System according to Article 3(1) (a) to (d) and any underlying obstacles for efficient undertaking of the equipment modification/refitting.

The Relevant National Regulatory Authority shall decide on the case within three months after receipt of the report and the recommendation of the Relevant TSO. The decision of the Relevant TSO on how to proceed with the issue and the decision of the National Regulatory Authority, if any, shall be published.

7. All relevant clauses in contracts and/or relevant clauses in general terms and conditions relating to the grid connection of Existing HVDC System Owners shall be amended to achieve compliance with the requirements of this Network Code, that shall apply to them according to Article 64(6). The relevant clauses shall be amended within three years after the decision of the National Regulatory Authority on the applicability according to Article 64(6). This requirement for amendment shall apply regardless of whether the relevant contracts or general terms and conditions provide for such an amendment.

#### **SECTION 4 OPERATIONAL NOTIFICATION PROCEDURE FOR EXISTING DC-CONNECTED POWER PARK MODULES**

##### *Article 65*

##### **General provisions**

1. In order to assess the advantages of the applicability of any requirement set forth in this Network Code to Existing DC-connected Power Park Modules, the Relevant TSO shall initiate a preparatory process aimed at identifying cases of merit with the phases defined in Article 65(2) to (8) below. This preparatory process shall consist of a qualitative comparison of costs and benefits related to the requirement under consideration for application to Existing DC-connected Power Park Modules taking into account network-based or market-based alternatives, where applicable. If the Relevant TSO deems the cost of applying the requirement to be low and the benefit to be high then the case can proceed as defined below. If however, the cost is deemed high and or the benefit is deemed low then the Relevant TSO may not proceed further.
2. The TSO shall carry out a quantitative Cost-Benefit Analysis of a requirement under consideration for application to Existing DC-connected Power Park Modules that has demonstrated potential benefits as a result of the preparatory stage according to Article 65(1) above. This Cost-Benefit Analysis shall be followed by a public consultation. The public consultation shall include, amongst others, a proposal for a transition period for applying a requirement to Existing DC-connected Power Park Modules. Such a transition period should not exceed two years from the decision of the National Regulatory Authority on the applicability.

3. Existing DC-connected Power Park Module Owners and Relevant Network Operator(s) shall assist and contribute to this Cost-Benefit Analysis and provide the relevant data as requested by the Relevant TSO within three months after reception of the request, unless agreed otherwise.
4. The Cost-Benefit Analysis shall be undertaken using one or more of the following calculating principles:
  - net present value;
  - return on investment;
  - rate of return; and
  - time to break-even.

The quantified benefits shall include any marginal socio-economic benefits in terms of improvement of security of supply including, but not limited to:

- associated reduction in probability of loss of supply over the lifetime of the modification;
- the probable extent and duration of such loss of supply;
- the societal cost per hour of such loss of supply;

as well as benefits to the internal market in electricity, cross-border trade and integration of renewable energies including, but not limited to:

- Frequency response;
- reserve holding;
- Reactive Power provision;
- congestion management; and
- defence measures.

The quantified costs shall include as appropriate, but are not limited to:

- costs for implementing the requirement;
- any attributable loss of opportunity; and/or
- change in maintenance and operating costs.

5. If the socio-economic benefits outweigh the costs of applying the requirement under consideration to Existing DC-connected Power Park Modules, the Relevant TSO shall summarise the analysis within three months in a report which shall include a recommendation on how to proceed. This report shall be subject to public consultation. If, taking due account of the outcome of the public consultation, the Relevant TSO decides to proceed with the issue, the report including such consultation outcome and a proposal on the applicability of the requirement under consideration to Existing DC-connected Power Park Modules, shall be forwarded to the Relevant National Regulatory Authority within six months for decision.
6. The proposal by the Relevant TSO to the National Regulatory Authority on applicability of any requirement of this Network Code according to Article 65(5) to Existing DC-connected Power Park Modules shall include the following:
  - a) an operational notification procedure in order to demonstrate the implementation of the requirements by the Existing DC-connected Power Park Modules Owner;
  - b) an appropriate transition period for implementing the requirements. The determination of the transition period shall take into account any underlying obstacles for efficient undertaking of the equipment modification/refitting.

The Relevant National Regulatory Authority shall decide on the case within three months after receipt of the report and the recommendation of the Relevant TSO. The decision of the Relevant

TSO on how to proceed with the issue and the decision of the National Regulatory Authority, if any, shall be published.

7. All relevant clauses in contracts and/or relevant clauses in general terms and conditions relating to the grid connection of Existing DC-connected Power Park Modules Owners shall be amended to achieve compliance with the requirements of this Network Code, that shall apply to them according to Article 65(6). The relevant clauses shall be amended within three years after the decision of the National Regulatory Authority on the applicability according to Article 65(6). This requirement for amendment shall apply regardless of whether the relevant contracts or general terms and conditions provide for such an amendment.

DRAFT

## CHAPTER 6 COMPLIANCE

### SECTION 1 COMPLIANCE MONITORING

#### *Article 66* **Responsibility of the HVDC System Owner and DC-connected Power Park Module Owner**

1. The HVDC System Owner shall ensure that the HVDC System and HVDC Converter Station(s) are compliant with the requirements under this Network Code. This compliance shall be maintained throughout the lifetime of the facility.
2. The DC-connected Power Park Module Owner shall ensure that the DC-connected Power Park Module is compliant with the requirements under this Network Code. This compliance shall be maintained throughout the lifetime of the facility.
3. Planned modifications of the technical capabilities of the HVDC System, HVDC Converter Station or DC-connected Power Park Module with possible impact on its compliance to the requirements under this Network Code shall be notified to the Relevant TSO by the HVDC System Owner or DC-connected Power Park Module Owner before initiating such modification.
4. Any operational incidents or failures of a HVDC System, HVDC Converter Station or DC-connected Power Park Module that have impact on its compliance to the requirements of this Network Code shall be notified to the Relevant TSO by the HVDC System Owner or DC-connected Power Park Module Owner as soon as possible without any delay after the occurrence of such an incident.
5. Any foreseen test schedules and procedures to verify compliance of a HVDC System, HVDC Converter Station or DC-connected Power Park Module with the requirements of this Network Code shall be notified to the Relevant TSO by the HVDC System Owner or DC-connected Power Park Module Owner in due time and prior to their launch and shall be approved by the Relevant TSO.
6. The Relevant TSO shall be facilitated to participate in such tests and may record the performance of the HVDC Systems, HVDC Converter Stations or DC-connected Power Park Modules.

#### *Article 67* **Tasks of the Relevant Network Operator**

1. The Relevant Network Operator shall regularly assess the compliance of an HVDC System, HVDC Converter Station and DC-connected Power Park Module with the requirements under this Network Code throughout the lifetime of the HVDC System, HVDC Converter Station or DC-connected Power Park Module. The HVDC System Owner or DC-connected Power Park Module Owner shall be informed of the outcome of this assessment.
2. The Relevant Network Operator shall have the right to request that the HVDC System Owner or DC-connected Power Park Module Owner carries out compliance tests and simulations not only during the operational notification procedures according to CHAPTER 5, but repeatedly throughout the lifetime of the HVDC System, HVDC Converter Station or DC-connected

Power Park Module according to a plan or general scheme for repeated tests and simulations defined while respecting the provisions of Article 4(3) or after any failure, modification or replacement of any equipment that may have impact on the compliance with the requirements under this Network Code. The HVDC System Owner or DC-connected Power Park Module Owner shall be informed of the outcome of these compliance tests and simulations.

3. The Relevant Network Operator shall make publicly available the list of information and documents to be provided as well as the requirements to be fulfilled by the HVDC System Owner or DC-connected Power Park Module Owner in the frame of the compliance process. Such list shall, notably, cover the following information, documents and requirements:
  - all documentation and certificates to be provided by the HVDC System Owner or DC-connected Power Park Module Owner;
  - details of the technical data of the HVDC System, HVDC Converter Station or DC-connected Power Park Module with relevance to the grid connection;
  - requirements for models for steady-state and dynamic system studies;
  - timely provision of system data required to perform the studies;
  - studies by the HVDC System Owner or DC-connected Power Park Module Owner for demonstrating expected steady-state and dynamic performance referring to the requirements set forth in CHAPTER 2, CHAPTER 3 and CHAPTER 4 of this Network Code; and
  - conditions and procedures including the scope for registering Equipment Certificates.
  - conditions and procedures for use of relevant Equipment Certificates by the Power Generating Facility Owner instead of part of the activity for compliance as described in this Network Code.
4. The Relevant Network Operator shall make publicly available the allocation of responsibilities to the HVDC System Owner or DC-connected Power Park Module Owner and to the Network Operator for compliance testing, simulation and monitoring.
5. The Relevant Network Operator may partially or totally assign the performance of its compliance monitoring to third parties. In this case, the Relevant TSO shall ensure compliance of Article 6 of this Network Code by appropriate confidentiality commitments with the assignee.
6. The Relevant Network Operator shall not withhold unreasonably any operational notification as per CHAPTER 5, if compliance tests or simulations cannot be performed as agreed between the Relevant TSO and the HVDC System Owner or DC-connected Power Park Module Owner due to reasons which are in the sole control of the Relevant Network Operator.

## SECTION 2 COMPLIANCE TESTING

### Article 68 Compliance testing for HVDC Systems

1. The Equipment Certificate may be used instead of part of the tests below, provided that they are provided to the Relevant TSO.
  
2. With regard to the Reactive Power Capability test:
  - a) The HVDC Converter Unit or the HVDC Converter Station shall demonstrate its technical capability to provide leading and lagging Reactive Power capability according to Article 18.
  - b) The Reactive Power Capability test shall be carried out at maximum Reactive Power, both leading and lagging, and concerning the verification of the following parameters:
    - i. Operation at Minimum HVDC Active Power Transmission Capacity ...;
    - ii. Operation at Maximum HVDC Active Power Transmission Capacity; and
    - iii. Operation at Active Power Setpoint between those Minimum and Maximum HVDC Active Power Transmission Capacity.
  - c) The test is deemed passed, provided that the following conditions are cumulatively fulfilled:
    - i. the HVDC Converter Unit or the HVDC Converter Station has been operating no shorter than 1 hour at maximum Reactive Power, both leading and lagging, for each parameter as referred to in point b);
    - ii. the HVDC Converter Unit or the HVDC Converter Station demonstrates its capability to change to any Reactive Power target value within the applicable Reactive Power range within the specified performance targets of the relevant Reactive Power control scheme; and
    - iii. no action of any protection within the operation limits defined by Reactive Power capacity diagram occurs.
  
3. With regard to the Voltage Control Mode test:
  - a) The HVDC Converter Unit or the HVDC Converter Station shall demonstrate its capability to operate in Voltage control mode in the conditions set forth in Article 20(3).
  - b) The Voltage Control Mode test shall apply concerning the verification of the following parameters:
    - i. the implemented Slope and deadband of the static characteristic;
    - ii. the accuracy of the regulation;
    - iii. the insensitivity of the regulation; and
    - iv. the time of Reactive Power activation.
  - c) The test is deemed passed, provided that the following conditions are cumulatively fulfilled:
    - i. the implemented Slope and deadband of the static characteristic;
    - ii. the range of regulation and adjustable the Droop and deadband is compliant with agreed or decided characteristic parameters, according to Article 20(3) ;
    - iii. the insensitivity of Voltage Control is not higher than 0.01 pu, according to Article 20(3); and
    - iv. following a step change in Voltage, 90 % of the change in Reactive Power output has been achieved within the times and tolerances according to Article 20(3).
  
4. With regard to the Reactive Power Control Mode test:

- a) The HVDC Converter Unit or the HVDC Converter Station shall demonstrate its capability to operate in Reactive Power control mode, according to the conditions referred to in Article 20(4).
  - b) The Reactive Power Control Mode test shall be complementary to the Reactive Power Capability test.
  - c) The Reactive Power Control Mode test shall apply concerning the verification of the following parameters:
    - i. the Reactive Power Setpoint range and step;
    - ii. the accuracy of the regulation; and
    - iii. the time of Reactive Power activation.
  - d) The test is deemed passed, provided that the following conditions are cumulatively fulfilled:
    - i. the Reactive Power Setpoint range and step is ensured according to Article 20(4); and
    - ii. the accuracy of the regulation is compliant with the conditions as referred to in Article 20(4).
5. With regard to the Power Factor Control Mode test:
- a) The HVDC Converter Unit or the HVDC Converter Station shall demonstrate its capability to operate in Power Factor control mode according to the conditions referred to in Article 20(5)
  - b) The Power Factor Control Mode test shall apply concerning the verification of the following parameters:
    - i. the Power Factor Setpoint range;
    - ii. the accuracy of the regulation; and
    - iii. the response of Reactive Power due to step change of Active Power.
  - c) The test is deemed passed, provided that the following conditions are cumulatively fulfilled:
    - i. the Power Factor Setpoint range and step is ensured according to Article 20(5);
    - ii. the time of Reactive Power activation as result of step Active Power change does not exceed the requirement according to Article 20(5); and
    - iii. the accuracy of the regulation is compliant with the value, as referred to in Article 20(5).
6. With regard to the FSM response test:
- a) The HVDC System shall demonstrate its technical capability to continuously modulate Active Power over the full operating range between Maximum HVDC Active Power Transmission Capacity and Minimum Regulating Level to contribute to Frequency Control and shall verify the steady-state parameters of regulations, such as Droop and deadband and dynamic parameters, including robustness through Frequency step change response and large, fast Frequency changes.
  - b) The test shall be carried out by simulating Frequency steps and ramps big enough to activate the whole Active Power Frequency response range, taking into account the Droop settings, the deadband and the Real Power headroom or deload (margin to Maximum HVDC Active Power Transmission Capacity in operational timescale). Simulated Frequency deviation signals shall be injected simultaneously into the references of both the speed governor and the load controller of the unit or plant control system if required, taking into account the speed governor and load controller scheme.

- c) The test is deemed to be passed, provided that the following conditions are all fulfilled:
  - i. activation time of full Active Power Frequency response range as result of a step Frequency change has been no longer than required by Article 11(1) (c);
  - ii. undamped oscillations do not occur after the step change response;
  - iii. the initial delay time has been according to Article 11(1) (c);
  - iv. the Droop settings are available within the range defined in Article 11(1) (c) and deadband (thresholds) is not more than the value in Article 11(1) (c); and
  - v. insensitivity of Active Power Frequency response at any relevant operating point does not exceed the requirements set forth in Article 11(1) (c).
  
7. With regard to the LFSM-O response test:
  - a) The HVDC System shall demonstrate its technical capability to continuously modulate Active Power to contribute to Frequency Control in case of large increase of Frequency in the system and shall verify the steady-state parameters of regulations, such as Droop and deadband, and dynamic parameters, including Frequency step change response.
  - b) The test shall be carried out by simulating Frequency steps and ramps big enough to activate at least 10 % of Maximum Capacity change in Active Power, taking into account the Droop settings and the deadband. Simulated Frequency deviation signals shall be injected simultaneously at both the speed and power control loops of the control systems if required, taking in account the scheme of these control system.
  - c) The test is deemed passed, provided that the following conditions are both fulfilled:
    - i. the test results, for both dynamic and static parameters, are in line with the requirements as referred to in Article 12(1); and
    - ii. undamped oscillations do not occur after the step change response.
  
8. With regard to the LFSM-U response test:
  - a) The HVDC System shall demonstrate its technical capability to continuously modulate Active Power at operating points below Maximum Capacity to contribute to Frequency Control in case of large drop of Frequency in the system.
  - b) The test shall be carried out by simulating at appropriate Active Power load points (e.g. 80 %) with low Frequency steps and ramps big enough to activate at least 10 % of Maximum Capacity Active Power change, taking into account the Droop settings and the deadband. Simulated Frequency deviation signals shall be injected simultaneously into both the speed governor and the load controller references if required, taking into account the speed governor and the load controller scheme.
  - c) The test is deemed passed, provided that the following conditions are both fulfilled:
    - i. the test results, for both dynamic and static parameters, are in line with the requirements as referred to in Article 13(1); and
    - ii. undamped oscillations do not occur after the step change response.
  
9. With regard to the Active Power Controllability test:
  - a) The HVDC System shall demonstrate its technical capability to continuously modulate Active Power over the full operating range according to Article 9(1)a) and d).
  - b) The test shall be carried out by sending manual and automatic instructions by the Relevant TSO(s).
  - c) The test is deemed passed, provided that the following conditions are cumulatively fulfilled:
    - i. The HVDC System has demonstrated stable operation
    - ii. The time of adjustment of the Active Power is shorter than the delay defined by Relevant TSO(s) and HVDC System owner



- iii. The dynamic response of the HVDC System when receiving instructions aiming at providing FCR or FRR is compliant with the requirements for these products detailed in LFC&R code.
10. With regard to the ramping rate modification test:
- a) The HVDC System shall demonstrate its technical capability to adjust the ramping rate according to Article 9(2).
  - b) The test shall be carried out by sending instructions by the Relevant TSO(s)
  - c) The test is deemed passed, provided that the following conditions are cumulatively fulfilled:
    - i. Ramping rate is adjustable
    - ii. The HVDC System has demonstrated stable operation during ramping periods
11. With regard to the black start test, if applicable:
- a) The HVDC System shall demonstrate its technical capability to energise the busbar of the remote AC substation to which it is connected, within a time frame specified by the Relevant TSO, according to Article 35(3).
  - b) The test shall be carried out while the HVDC System starts from shut down.
  - c) The test is deemed passed, provided that the following conditions are cumulatively fulfilled:
    - i. The HVDC System has demonstrated being able to energise the busbar of the remote AC-substation to which it is connected
    - ii. The HVDC System operates from a stable operating point at agreed capacity, according to the procedure of Article 35(4).

**Article 69 Compliance testing for DC-connected Power Park Modules and Remote-end HVDC Converter Units**

- 1. The Equipment Certificate may be used instead of part of the tests below, provided that they are provided to the Relevant TSO.
- 2. With regard to the Reactive Power capability test of DC Connected PPMs:
  - a) The DC-connected Power Park Module shall demonstrate its technical capability to provide leading and lagging Reactive Power capability according to Article 38(2).
  - b) The Reactive Power Capability test shall be carried out at maximum Reactive Power, both leading and lagging, and concerning the verification of the following parameters:
    - 1) operation in excess of 60 % of Maximum Capacity for 30 minutes;
    - 2) operation within the range of 30 – 50 % of Maximum Capacity for 30 minutes; and
    - 3) operation within the range of 10 – 20 % of Maximum Capacity for 60 minutes.
  - c) The test is deemed passed, provided that the following criteria are cumulatively fulfilled:

- 1) the DC-connected Power Park Module has been operating no shorter than requested duration at maximum Reactive Power, both leading and lagging, in each parameter as referred to in Article 69(2)b;
  - 2) the DC-connected Power Park Module has demonstrated its capability to change to any Reactive Power target value within the agreed or decided Reactive Power range within the specified performance targets of the relevant Reactive Power control scheme; and
  - 3) no action of any protection within the operation limits defined by Reactive Power capacity diagram occurs.
3. With regard to the Reactive Power capability test of Remote-end HVDC Converter Units:
- a) The HVDC Converter Unit or the HVDC Converter Station shall demonstrate its technical capability to provide leading and lagging Reactive Power capability according to Article 46(2).
  - b) The test is deemed passed, provided that the following conditions are cumulatively fulfilled:
    - 1) the HVDC Converter Unit or the HVDC Converter Station has been operating no shorter than 1 hour at maximum Reactive Power, both leading and lagging, at:
      - Minimum Stable Operating Level;
      - Maximum Capacity; and
      - an Active Power operating point between those maximum and minimum ranges;
    - 2) the HVDC Converter Unit or the HVDC Converter Station demonstrates its capability to change to any Reactive Power target value within the agreed or decided Reactive Power range within the specified performance targets of the relevant Reactive Power control scheme; and
    - 3) no action of any protection within the operation limits defined by Reactive Power capacity diagram occurs.
4. With regard to the Voltage Control Mode test:
- a) The DC-connected Power Park Module shall demonstrate its capability to operate in Voltage control mode in the conditions set forth in Article 16(3) (d) point 2) of the [NC RfG].
  - b) The Voltage Control Mode test shall apply concerning the verification of the following parameters:
    - 1) the implemented Slope and deadband of the static characteristic;
    - 2) the accuracy of the regulation;
    - 3) the insensitivity of the regulation; and
    - 4) the time of Reactive Power activation.

- c) The test is deemed passed, provided that the following conditions are cumulatively fulfilled:
  - 1) the implemented Slope and deadband of the static characteristic;
  - 2) the range of regulation and adjustable the Droop and deadband is compliant with agreed or decided characteristic parameters, according to Article 16(3) (d) of the [NC RfG];
  - 3) the insensitivity of Voltage Control is not higher than 0.01 pu, according to Article 16(3) (d) of the [NC RfG]; and
  - 4) following a step change in Voltage, 90 % of the change in Reactive Power output has been achieved within the times and tolerances according to Article 16(3) (d) of the [NC RfG].
- 5. With regard to the Reactive Power Control Mode test:
  - a) The DC-connected Power Park Module shall demonstrate its capability to operate in Reactive Power control mode, according to the conditions referred to in Article 16(3) (d) point 3) of the [NC RfG].
  - b) The Reactive Power Control Mode test shall be complementary to the Reactive Power Capability test.
  - c) The Reactive Power Control Mode test shall apply concerning the verification of the following parameters:
    - 1) the Reactive Power Setpoint range and step;
    - 2) the accuracy of the regulation; and
    - 3) the time of Reactive Power activation.
  - d) The test is deemed passed, provided that the following conditions are cumulatively fulfilled:
    - 1) the Reactive Power Setpoint range and step is ensured according to Article 16(3) (d) of the [NC RfG]; and
    - 2) the accuracy of the regulation is compliant with the conditions as referred to in Article 16(3) (d) of the [NC RfG].
- 6. With regard to the Power Factor Control Mode test:
  - a) The DC-connected Power Park Module shall demonstrate its capability to operate in Power Factor control mode according to the conditions referred to in Article 16(3) (d) point 4) of the [NC RfG].
  - b) The Power Factor Control Mode test shall apply concerning the verification of the following parameters:
    - 1) the Power Factor Setpoint range;
    - 2) the accuracy of the regulation; and
    - 3) the response of Reactive Power due to step change of Active Power.

- a) The test is deemed passed, provided that the following conditions are cumulatively fulfilled:
- 1) the Power Factor Setpoint range and step is ensured according to Article 16(3) (d) of the [NC RfG];
  - 2) the time of Reactive Power activation as result of step Active Power change does not exceed the requirement according to Article 16(3) (d) of the [NC RfG]; and
  - 3) the accuracy of the regulation is compliant with the value, as referred to in Article 16(3) (d) of the [NC RfG].
7. With regard to the tests identified in this Section in paragraphs (3), (4) and (5) the Relevant TSO may select only two of the three control options for testing.
  8. With regard to LFSM-O response of DC-Connected Power Park Module, the tests shall be carried out in accordance with Article 41 (2) of [NC RfG].
  9. With regard to LFSM-U response of DC-Connected Power Park Module, the tests shall be carried out in accordance with Article 42(3) of [NC RfG].
  10. With regard to active power controllability of DC-Connected Power Park Module, the tests shall be carried out in accordance with 42(2) of [NC RfG].
  11. With regard to FSM response of DC-Connected Power Park Module, the tests shall be carried out in accordance with Article 42(4) of [NC RfG].
  12. With regard to Frequency restoration control of DC-Connected Power Park Module, the tests shall be carried out in accordance with Article 42(5) of [NC RfG].
  13. With regard to fast signal response of DC-Connected Power Park Module, the test is deemed passed if the DC-Connected Power Park Module can demonstrate its response within the time specified in Article 37(1)a).
  14. With regard to tests for DC-Connected Power Park Modules where the AC collector system is not at nominal 50 Hz Frequency, the Relevant TSO shall define and agree with the DC-Connected Power Park Module Owner the compliance tests required.
  - 15.

### **SECTION 3 COMPLIANCE SIMULATIONS**

#### *Article 70* **Compliance simulations for HVDC Systems**

1. The Equipment Certificate may be used instead of part of the simulations below, provided that they are provided to the Relevant TSO.
2. With regard to the fast acting additional reactive Current injection simulation:
  - a) The HVDC Converter Unit or the HVDC Converter Station shall demonstrate its capability to simulate fast acting additional reactive Current injection in the conditions set forth in Article 17.

- b) The simulation is deemed passed, provided that compliance with the requirement according to Article 17 is demonstrated.
3. With regard to the fault-ride-through capability simulation:
- a) The HVDC System shall demonstrate its capability to simulate fault-ride-through capability in the conditions set forth in Article 23.
- b) The simulation is deemed passed, provided that compliance with the requirement according to Article 23 is demonstrated.
4. With regard to the Post Fault Power Active Recovery simulation:
- a) The HVDC System shall demonstrate its capability to simulate post fault Active Power recovery in the conditions set forth in Article 24.
- b) The simulation is deemed passed, provided that compliance with the requirement according to Article 24 is demonstrated.
5. With regard to the Reactive Power capability simulation:
- a) The HVDC Converter Unit or the HVDC Converter Station shall demonstrate its capability to simulate leading and lagging Reactive Power capability in the conditions referred to in Article 18(1)(b)-(d).
- b) The simulation is deemed passed, provided that the following conditions are cumulatively fulfilled:
- i. the simulation model of the HVDC Converter Unit or the HVDC Converter Station is validated against the compliance tests for Reactive Power Capability at the as referred to in Article 68; and
  - ii. compliance with the requirements as referred to in Article 18(3) (b)- (d) is demonstrated.
6. With regard to the Power Oscillations Damping Control simulation:
- a) The HVDC System shall demonstrate the performance of its control system (POD function) to damp power oscillations in the conditions set forth in Article 28.
- b) The tuning shall result in improved damping of corresponding Active Power response of the HVDC control in combination with the POD function compared to the Active Power response of the HVDC control alone.
- c) The simulation is deemed passed, provided that the following conditions are cumulatively fulfilled:
- i. The POD function damps the existing power oscillations of the HVDC System within a Frequency range specified by the Relevant TSO. This Frequency range shall include the local mode Frequency of the HVDC System and the expected Network oscillations; and
  - ii. a sudden load reduction of the HVDC System from 1 p.u. to 0.6 p.u. of the Maximum HVDC Active Power Transmission Capacity has not lead to undamped oscillations in Active or Reactive Power of the HVDC System.
7. With regard to the simulation of Active Power modification in case of disturbance:
- a) The HVDC System shall demonstrate its technical capability to modify quickly Active Power according to Article 9(1)(b).
- b) The simulation is deemed passed, provided that the following conditions are cumulatively fulfilled:

- i. The HVDC System has demonstrated stable operation when following the pre-defined sequence of active power variation.
  - ii. The initial delay of the adjustment of the Active Power is shorter than the value specified in Article 9(1)(b) or reasonably justified if greater
8. With regard to the fast active power reversal simulation, as applicable:
  - a) The HVDC System shall demonstrate its technical capability to modify quickly Active Power according to Article 9(1)(c).
  - b) The simulation is deemed passed, provided that the following conditions are cumulatively fulfilled:
    - i. The HVDC System has demonstrated stable operation
    - ii. The time of adjustment of the Active Power is shorter than the value specified in Article 9(1)(c) or reasonably justified if greater

**Article 71 Compliance simulations for DC-connected Power Park Modules and Remote-end HVDC Converter Units**

1. DC-connected Power Park Modules are subject to the following compliance simulations. The Equipment Certificate may be used instead of part of the simulations below, provided that they are provided to the Relevant TSO.
2. With regard to the fast acting additional reactive Current injection simulation:
  - a) The DC-connected Power Park Module shall demonstrate its capability to simulate fast acting additional reactive Current injection in the conditions set forth in Article 15(2) (b) of the [NC RfG].
  - b) The simulation is deemed passed, provided that compliance with the requirement according to Article 15(2) (b) of the [NC RfG] is demonstrated.
3. With regard to the Post Fault Power Active Recovery simulation:
  - a) The DC-connected Power Park Module shall demonstrate its capability to simulate post fault Active Power recovery in the conditions set forth in Article 15(3) (a) of the [NC RfG].
  - b) The simulation is deemed passed, provided that compliance with the requirement according to Article 15(3) (a) of the [NC RfG] is demonstrated.
4. With regard to the Reactive Power capability simulation of DC connected PPMs:
  - a) The DC-connected Power Park Module shall demonstrate its capability to simulate leading and lagging Reactive Power capability in the conditions referred to in Article 16(3) (b) and (c) of the [NC RfG].
  - b) The simulation is deemed passed, provided that the following conditions are cumulatively fulfilled:
    - 1) the simulation model of the DC-connected Power Park Module is validated against the compliance tests for Reactive Power Capability at the as referred to in Article 42(6) of the [NC RfG]; and

- 2) compliance with the requirements as referred to in Article 16(3) (b) and (c) of the [NC RfG] is demonstrated.
5. With regard to the Reactive Power capability simulation of Remote-end HVDC Converter Units:
  - a) The Remote-end HVDC Converter Unit or the Remote-end HVDC Converter Station shall demonstrate its capability to simulate leading and lagging Reactive Power capability in the conditions referred to in Article 46 (2).
  - b) The simulation is deemed passed, provided that the following conditions are cumulatively fulfilled:
    - 1) the simulation model of the Remote-end HVDC Converter Unit or the HVDC Converter Station is validated against the compliance tests for Reactive Power Capability at the as referred to in Article 69(2); and
    - 2) compliance with the requirements as referred to in Article 46 (2) is demonstrated.
6. With regard to the power oscillations damping control simulation:
  - a) The model of the DC-connected Power Park Module shall demonstrate its capability to simulate power oscillations damping capability in the conditions as referred to in Article 16(3) (f) of the [NC RfG].
  - b) The simulation is deemed passed, provided that the model demonstrates compliance with the conditions of Article 16(3) (f) of the [NC RfG].
7. The model of the DC-connected Power Park Module shall demonstrate its capability to simulate fault-ride-through capability in the conditions as referred to in Article 11(3) (a) of the [NC RfG].

The simulation is deemed passed, provided that the model demonstrates compliance with the conditions of Article 11(3) (a) of the [NC RfG] respectively.

## CHAPTER 7 DEROGATIONS

### *Article 72*

#### **General Provisions**

1. The procedure for Derogation defined in this Chapter applies to all HVDC Systems, and DC-connected Power Park Modules, both existing and new, to which the provisions of this Network Code are applicable pursuant to Article 3.
2. The request for Derogation in Article 72(1) can only be submitted by the HVDC System Owner for its HVDC System, HVDC Converter Station or HVDC Converter Unit, or by the DC-connected Power Park Module Owner for its DC-connected Power Park Module.
3. It shall also apply to Network Operators when applying for Derogations for classes of both existing and new HVDC Systems, as well as existing or new DC-connected Power Park Modules connected to their Network.
4. The Derogation process shall be transparent, non-discriminatory, non-biased, well documented and based in particular on the Cost Benefit Analysis performed in the conditions set forth by Article 64 and Article 65 by the Relevant TSO. A Cost Benefit Analysis may not be performed by the Relevant TSO if, on its reasoned request, an individual exception is granted to the Relevant TSO by the National Regulatory Authority.
5. Criteria for assessing the request for Derogation shall be set by the Relevant National Regulatory Authority taking into account the recommendation of the Relevant Network Operator in coordination with the Relevant TSO. The criteria set by the Relevant National Regulatory Authority shall be non-discriminatory, objective and be published by the Relevant National Regulatory Authority.

### *Article 73*

#### **Request for Derogation**

1. HVDC System Owners to which the provisions of this Network Code apply may apply for Derogation. The request for Derogation may relate to one or several requirements of this Network Code.
2. DC-connected Power Park Module Owners to which the provisions of this Network Code apply may apply for Derogation. The request for Derogation may relate to one or several requirements of this Network Code.
3. The request for Derogation shall be submitted to the Relevant Network Operator. If the HVDC System is connecting Synchronous Areas or Control Areas, the request for Derogation shall be submitted to each of the Relevant TSOs of the affected Control Areas.
4. The request for Derogation, submitted by the HVDC System Owner or by the DC-connected Power Park Module Owner shall include all the information and documents which are required by the Relevant Network Operator in coordination with the Relevant TSO, including, but not limited to:



- a) identification data of the applicant party, with reference contact person for any communications;
  - b) the specific plant or site to which the request is referred to;
  - c) the provision of the Network Code for which a Derogation is requested, with the detailed description of the requested Derogation; and
  - d) detailed accompanying justification with all relevant documents supporting the derogation application.
5. A DSO or CDSO may apply for derogation in respect of one or more requirements of this Network Code by submitting a request to the Relevant TSO.
6. The request for derogation, submitted by the DSO or CDSO shall include all the information and documents which are required by the Relevant TSO, including, inter alia, but not limited to:
- a) identifying data of the DSO or CDSO, with reference contact person for any communications;
  - b) the number of HVDC Systems and DC-connected Power Park Modules affected and the total installed capacity to which the request is referred to;
  - c) the provision of the Network Code for which a derogation is requested, with the detailed description of the requested derogation;
  - d) detailed reasoning accompanied with all relevant documents supporting the request.
7. A TSO may apply for derogation in respect of one or more requirements of this Network Code by submitting a request to the National Regulatory Authority.
8. The request for derogation, submitted by the TSO shall include the following information:
- a) identifying data of the TSO, with reference contact person for any communications;
  - b) the number of HVDC Systems and DC-connected Power Park Modules affected and the total installed capacity to which the request is referred to;
  - c) the provision of the Network Code for which a derogation is requested, with the detailed description of the requested derogation;
  - d) detailed reasoning accompanied with all relevant documents supporting the request.

#### *Article 74*

#### **Decision on Derogation**

1. Further to the request for derogation submitted by a HVDC System Owner or DC-connected Power Park Module Owner, the Relevant Network Operator shall assess the request and related documentation. If the request or the related documentation is considered to be incomplete the HVDC System Owner or DC-connected Power Park Module Owner shall submit the missing information as requested by the Relevant Network Operator. As from the day of the receipt of the complete request from the HVDC System Owner, or DC-connected Power Park Module Owner until the issuance of the decision granting or refusing the derogation by the National Regulatory Authority according to Article 74(10), the HVDC System, HVDC Converter Station, HVDC Converter Unit or DC-connected Power Park Module to which the request is referred to are deemed as compliant.
2. No later than six months after the receipt of the complete request according to Article 74(1) the Relevant Network Operator shall submit to the Relevant National Regulatory Authority its assessment of the request, including a reasoned opinion, together with a related documentation and, where applicable, a Cost-Benefit Analysis.

3. The above deadline shall be shortened to three months in case a reasoned request for exemption from Cost-Benefit Analysis is submitted by the Relevant TSO to the National Regulatory Authority.
4. Except for a Type A or B Power Generating Module connected to a distribution Network or closed distribution Network, and their associated HVDC System, the DSO or CDSO shall obtain the assessment of the Relevant TSO within two months after notification to the Relevant TSO by the Relevant Network Operator and include it in its submission to the National Regulatory Authority.
5. If the Relevant Network Operator has requested an exemption from Cost-Benefit Analysis the National Regulatory Authority shall decide on granting or refusing the exemption within one month after the receipt of this request. If the request is rejected, the Relevant Network Operator shall provide a Cost-Benefit Analysis within three months following the decision of the National Regulatory Authority.
6. Further to the request for derogation submitted by a DSO or CDSO, the Relevant TSO shall assess the request and related documentation. If the request or the related documentation is considered to be incomplete the DSO or CDSO shall submit the missing information as requested by the Relevant TSO. As from the day of the receipt of the complete request by the DSO or CDSO until the issuance of the decision granting or refusing the derogation by the National Regulatory Authority according to Article 74(10), the HVDC Systems of Power Generating Facilities to which the request is referred to are deemed as compliant.
7. No later than six months after the receipt of the complete request according to Article 74 (6) the TSO shall submit its assessment of the request, including a reasoned opinion, together with a related documentation and, where applicable, a Cost-Benefit Analysis performed by the DSO or CDSO.

The above deadline shall be shortened to three months in case a reasoned request for exemption from Cost-Benefit Analysis is submitted by the DSO or CDSO to the National Regulatory Authority.

If the DSO or CDSO has requested an exemption from Cost-Benefit Analysis the National Regulatory Authority shall decide on granting or refusing the exemption within one month after the receipt of this request. If the request is rejected, the DSO or CDSO shall provide a Cost-Benefit Analysis within three months following the decision of the National Regulatory Authority.

8. Further to the request for derogation submitted by the TSO, the National Regulatory Authority shall assess the request and related documentation. If the request or the related documentation is considered to be incomplete the TSO shall submit the missing information as requested by the National Regulatory Authority. As from the day of the receipt of the complete request by the TSO until the issuance of the decision granting or refusing the derogation by the National Regulatory Authority according to Article 74(10), the HVDC Systems or Power Generating Facilities to which the request is referred to are deemed as compliant.
9. Together with the request according to Article 74(8) the TSO shall submit either a Cost-Benefit Analysis or a reasoned request for exemption from Cost-Benefit Analysis to the National Regulatory Authority. If the TSO has requested an exemption from Cost-Benefit Analysis the National Regulatory Authority shall decide on granting or rejecting this request within one month

after the receipt of this request. When the request is rejected, the TSO shall provide a Cost-Benefit Analysis within three months following the decision of the National Regulatory Authority.

10. The National Regulatory Authority shall issue a motivated decision granting or refusing the derogation and specifying the duration of the derogation, including a reasoned opinion, within a further three months after receipt of the complete documentation.
11. The National Regulatory Authority shall communicate to the applicant, the Relevant Network Operator and the Agency the decision granting or rejecting the derogation. In case the applicant is a DSO or CDSO, the Relevant TSO shall be informed as well.
12. The Agency shall monitor the procedures of derogation and the National Regulatory Authority shall cooperate with the Agency in this task and shall provide the Agency with all information necessary for this purpose.
13. The Agency may issue a reasoned recommendation to the National Regulatory Authority to revoke any derogation, which has been granted without due justification.
14. The National Regulatory Authority shall have the right to issue a motivated decision revoking the granted derogation under the conditions and pursuant to the provisions of national law reserving the vested interests of the concerned grid users, in the cases where the prerequisites for granting the derogation no longer exist for reasons attributable to the concerned grid users.

#### *Article 75*

##### **Compliance of Existing HVDC Systems and Existing DC-connected Power Park Modules**

1. The owner of an Existing HVDC System or Existing DC-connected Power Park Module, deemed significant in accordance with the procedure set forth in Article 64 and Article 65, which is not compliant with at least one requirement of the Network Code, shall apply for a Derogation from these requirements in accordance with Article 73, within twelve months from the date the requirement, with which it is not compliant, becomes applicable.
2. If one month before the expiry of the twelve-month period set in Article 75(1), no application for Derogation has been received, the Relevant Network Operator shall, by formal notice, require the non-compliant Existing HVDC System or Existing DC-connected Power Park Module System, to either conform with the requirement, or to apply for a Derogation.
3. If at the expiry of the twelve-month period, the owner of the non-compliant Existing HVDC System or Existing DC-connected Power Park Module System referred to in Article 75(1) has not applied for a Derogation, the Relevant Network Operator shall have the right to refuse operation of the Existing HVDC System or Existing DC-connected Power Park Module System. The decision on refusal of operation shall be motivated.

#### *Article 76*

##### **Register of derogations to the Network Code**

1. Each National Regulatory Authority shall maintain and publish a register of all Derogations granted or rejected and shall provide to the Agency an updated and consolidated register at least every 6 months, with a copy to ENTSO-E.

2. These registers shall contain in particular:
- a) the requirement(s) for which the derogation is granted or refused;
  - b) content of the derogation;
  - c) consequences of the granting of the derogation;
  - d) reasons for granting or refusing the derogation; and
  - e) whether the exemption from the performance of the cost-benefit analysis was granted.

DRAFT

## CHAPTER 8 FINAL PROVISIONS

### *Article 77*

#### **Amendment of contracts and general terms and conditions**

All relevant clauses in contracts and/or relevant clauses in general terms and conditions relating to the Network connection of New HVDC Systems, New HVDC Converter Stations, New HVDC Converter Units or New DC-connected Power Park Modules shall be amended to achieve compliance with the requirements of this Network Code.

The relevant clauses shall be amended within three years after the entry into force of this Network Code.

This requirement for amendment shall apply regardless of whether the relevant contracts or general terms and conditions provide for such an amendment.

### *Article 78*

#### **Entry into force**

This Network Code shall enter into force on the twentieth day following that of its publication in the Official Journal of the European Union.

With the exception of Article 3(7) and (8), which shall apply thirty months after the entry into force, all provisions of this Network Code shall apply as from the day of expiration of a three year period following its publication.

This Network Code shall be binding in its entirety and directly applicable in all Member States.