

Operating Style	Series Numbers	Tested Size	OA	Glass 1	Glass 2	Glass 3	Spacer		STC	OITC	Test Date	Test Number
							Intercept or Cardinal	Foam or Dura****				
horizontal slider	2110 2111 2130 2130J 2170	59" x 47"	3/4"	1/8	1/8	-	x	<--	29	24	04/25/23	<a href="#">TL23-149</a>
				1/8	3/16	-	x	<--	33	28	04/25/23	<a href="#">TL23-150</a>
				1/8	LAM	-	-->	x	34	29	04/25/23	<a href="#">TL23-151</a>
				3/16	3/16	-	x	<--	31	26	04/26/23	<a href="#">TL23-153</a>
				3/16	1/4	-	-->	x	33	29	04/26/23	<a href="#">TL23-154</a>
				1/4	1/4	-	-->	x	32	29	04/26/23	<a href="#">TL23-155</a>
				1/4	LAM	-	-->	x	33	29	04/26/23	<a href="#">TL23-157</a>
vertical slider	2210 2211 2230 2230J 2270	47" x 59"	3/4"	1/8	1/8	-	x	<--	30	25	08/23/23	<a href="#">TL23-331</a>
				1/8	3/16	-	x	<--	33	29	08/23/23	<a href="#">TL23-333</a>
				1/8	LAM	-	-->	x	33	29	08/23/23	<a href="#">TL23-334</a>
				3/16	3/16	-	x	<--	31	28	08/23/23	<a href="#">TL23-336</a>
				3/16	1/4	-	-->	x	32	29	08/23/23	<a href="#">TL23-338</a>
				1/4	1/4	-	-->	x	32	30	08/24/23	<a href="#">TL23-339</a>
				1/4	LAM	-	-->	x	34	31	08/24/23	<a href="#">TL23-340</a>
fixed - slider frame	2310 2311 2331 2331J 2370	47" x 59"	3/4"	1/8	1/8	-	x	<--	28	24	05/12/23	<a href="#">TL23-214</a>
				1/8	3/16	-	x	<--	32	27	05/12/23	<a href="#">TL23-215</a>
				1/8	LAM	-	-->	x	33	29	05/12/23	<a href="#">TL23-216</a>
				3/16	3/16	-	x	<--	31	27	05/12/23	<a href="#">TL23-217</a>
				3/16	1/4	-	-->	x	34	30	05/12/23	<a href="#">TL23-218</a>
				1/4	1/4	-	-->	x	33	29	05/12/23	<a href="#">TL23-219R1</a>
				1/4	LAM	-	-->	x	35	30	05/12/23	<a href="#">TL23-220</a>
fixed - step frame	2340 2341 2330 2330J	47" x 59"	1"	1/8	1/8	-	x	<--	29	24	04/25/23	<a href="#">TL23-141</a>
				1/8	3/16	-	x	<--	33	26	04/25/23	<a href="#">TL23-142</a>
				1/8	LAM	-	-->	x	34	28	04/25/23	<a href="#">TL23-143</a>
				3/16	3/16	-	x	<--	31	24	04/25/23	<a href="#">TL23-144</a>
				3/16	1/4	-	x	<--	34	28	04/25/23	<a href="#">TL23-145</a>
				1/4	1/4	-	x	<--	32	27	04/25/23	<a href="#">TL23-146</a>
				1/4	LAM	-	-->	x	34	28	04/25/23	<a href="#">TL23-147</a>
fixed - FA/FC match	2350T 2351T 2360T 2375T	47" x 59"	7/8"	1/8	1/8	-	x	<--	29	24	05/11/23	<a href="#">TL23-207</a>
				1/8	3/16	-	x	<--	33	26	05/11/23	<a href="#">TL23-208</a>
				1/8	LAM	-	-->	x	34	29	05/11/23	<a href="#">TL23-209</a>
				3/16	3/16	-	x	<--	32	27	05/11/23	<a href="#">TL23-210</a>
				3/16	1/4	-	x	<--	33	28	05/11/23	<a href="#">TL23-211</a>
				1/4	1/4	-	x	<--	32	27	05/11/23	<a href="#">TL23-212</a>
				1/4	LAM	-	-->	x	35	30	05/11/23	<a href="#">TL23-213</a>

Operating Style	Series Numbers	Tested Size	OA	Glass 1	Glass 2	Glass 3	Spacer		STC	OITC	Test Date	Test Number
							Intercept or Cardinal	Foam or Dura****				
awning ( flat sash )	2410T 2411T 2430T 2470T	59" x 24"	7/8"	1/8	1/8	-	x	<--	29	25	08/22/23	<a href="#">TL23-314</a>
				1/8	3/16	-	x	<--	32	28	08/22/23	<a href="#">TL23-315</a>
				1/8	LAM	-	-->	x	33	29	08/22/23	<a href="#">TL23-328</a>
				3/16	3/16	-	x	<--	30	26	08/22/23	<a href="#">TL23-318</a>
				3/16	1/4	-	x	<--	33	29	08/22/23	<a href="#">TL23-319</a>
				1/4	1/4	-	x	<--	32	28	08/22/23	<a href="#">TL23-320</a>
				1/4	LAM	-	-->	x	32	28	08/22/23	<a href="#">TL23-322</a>
casement ( flat sash )	2510T 2511T 2530T 2570T	24" x 59"	7/8"	1/8	1/8	-	x	<--	30	26	08/22/23	<a href="#">TL23-323</a>
				1/8	3/16	-	x	<--	34	30	08/22/23	<a href="#">TL23-324</a>
				1/8	LAM	-	-->	x	35	30	08/22/23	<a href="#">TL23-325</a>
				3/16	3/16	-	x	<--	33	27	08/22/23	<a href="#">TL23-326</a>
				3/16	1/4	-	x	<--	35	30	08/22/23	<a href="#">TL23-327</a>
				1/4	1/4	-	x	<--	35	30	08/23/23	<a href="#">TL23-329</a>
				1/4	LAM	-	-->	x	37	32	08/23/23	<a href="#">TL23-330</a>
sliding door	2610 2611 2630 2670	79" x 79"	1"	1/8	1/8	-	x	<--	30	24	08/24/23	<a href="#">TL23-342</a>
				1/8	3/16	-	x	<--	34	27	08/24/23	<a href="#">TL23-341</a>
				1/8	LAM	-	-->	x	36	29	08/24/23	<a href="#">TL23-346</a>
				3/16	3/16	-	x	<--	32	26	08/24/23	<a href="#">TL23-344</a>
				3/16	1/4	-	x	<--	34	28	08/24/23	<a href="#">TL23-345</a>
				1/4	1/4	-	x	<--	33	27	08/24/23	<a href="#">TL23-343</a>
				1/4	LAM	-	-->	x	37	30	08/24/23	<a href="#">TL23-349</a>
transom	2610 2630 2670	79" x 24"	7/8"	1/8	1/8	-	-->	x	29	25	06/08/23	<a href="#">TL23-244</a>
				1/8	3/16	-	-->	x	35	28	06/08/23	<a href="#">TL23-245</a>
				1/8	LAM	-	-->	x	37	30	06/08/23	<a href="#">TL23-246</a>
				3/16	3/16	-	-->	x	34	27	06/08/23	<a href="#">TL23-247</a>
				3/16	1/4	-	-->	x	36	29	06/08/23	<a href="#">TL23-248</a>
				1/4	1/4	-	-->	x	34	27	06/08/23	<a href="#">TL23-249</a>
				1/4	LAM	-	-->	x	34	29	06/08/23	<a href="#">TL23-250</a>